This is an electronic reprint of the original article.
This reprint may differ from the original in pagination and typographic detail.

Pourakbari-Kasmaei, Mahdi; Lehtonen, Matti; Contreras, Javier; Mantovani, José Roberto Sanches

Carbon Footprint Management

Published in:
IEEE Transactions on Industrial Informatics

DOI:
[10.1109/TII.2019.2922394](https://doi.org/10.1109/TII.2019.2922394)

Published: 01/01/2019

Document Version
Peer reviewed version

Please cite the original version:
Pourakbari-Kasmaei, M., Lehtonen, M., Contreras, J., & Mantovani, J. R. S. (2019). Carbon Footprint Management: A Pathway toward Smart Emission Abatement. *IEEE Transactions on Industrial Informatics*, 16(2), 935-948. <https://doi.org/10.1109/TII.2019.2922394>

This material is protected by copyright and other intellectual property rights, and duplication or sale of all or part of any of the repository collections is not permitted, except that material may be duplicated by you for your research use or educational purposes in electronic or print form. You must obtain permission for any other use. Electronic or print copies may not be offered, whether for sale or otherwise to anyone who is not an authorised user.

© 2019 IEEE. This is the author's version of an article that has been published by IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other uses, in any current or future media, including reprinting/republishing this material for advertising or promotional purposes, creating new collective works, for resale or redistribution to servers or lists, or reuse of any copyrighted component of this work in other works.

Carbon Footprint Management: A Pathway toward Smart Emission Abatement

Mahdi Pourakbari-Kasmaei, *Member, IEEE*, Matti Lehtonen, Javier Contreras, *Fellow, IEEE*, and José Roberto Sanches Mantovani, *Member, IEEE*

Abstract—There is an increasing concern about controlling and reducing carbon emissions in power systems. In this regard, researchers have focused on managing emissions on the generation side, which is the main source of emissions. Considering emission limits on the generation side results in an increase in locational marginal prices that negatively affects social welfare. However, carbon emissions are a by-product of electricity generation that is used to satisfy the demands on the consumer side. Consequently, demand side emission control may not be achieved if only generation is taken into account. In order to fill this existing gap, in this paper, a demand-side management approach aiming at carbon footprint control is proposed. First, the carbon footprint is allocated among the consumers using an improved proportional sharing theorem method. Each consumer learns about their real-time carbon footprint, excess carbon footprint, and the incurred surcharge tax. Then, demands are adjusted via a proper adjustment procedure. This provides enough information for consumers where demand management may result in carbon footprint and demand reductions as well as the exemption of incurred taxes. Profit analysis for both generation and demand sides is carried out to show the effectiveness of the proposed framework using two illustrative case studies. The results obtained, compared with existing policies such as carbon cap, cap-and-trade, and carbon tax, prove the fairness and the advantages of the proposed model for both the demand and the generation sides.

Index Terms—Carbon footprint allocation, carbon abatement, demand side management, power tracing, tax exemption.

NOMENCLATURE

A. Indexes and Sets

g	Index for generating unit.
i, j, n	Index for buses.
ij	Index for the line between bus i and j .
l	Index for transmission lines.
Ω_b	Set of buses.
Ω_D	Set of demands.
Ω_G	Set of generating units.
Ω_l	Set of transmission lines.

This work was supported by the FAPESP (No. 2014/22828-3, No. 2015/21972-6, and No. 2016/14319-7), CAPES, and CNPq (No. 305318/2016-0).

M. Pourakbari-Kasmaei and M. Lehtonen are with the Department of Electrical Engineering and Automation, Aalto University, Maarintie 8, 02150 Espoo, Finland (e-mails: Mahdi.Pourakbari@aalto.fi, Matti.Lehtonen@aalto.fi).

Javier Contreras is with the E.T.S. de Ingenieros Industriales, University of Castilla-La Mancha, 13071 Ciudad Real, Spain (e-mail: Javier.Contreras@uclm.es).

José Roberto Sanches Mantovani is with the Department of Electrical Engineering, Sao Paulo State University, Ilha Solteira 15385000, Brazil (e-mail: mant@dee.feis.unesp.br).

B. Parameters

a_i, b_i, c_i	Cost coefficients of unit i .
Cap	Carbon cap.
$\overline{DCF}_i$	Demand carbon footprint threshold at bus i .
$\overline{f}_{ij}$	Maximum power flow limit through line ij .
g_i^{sh} / b_i^{sh}	Shunt conductance/shunt susceptance of bus i .
$\underline{P}_G$	Lower limit of active power generation of unit i .
P_{D_i} / Q_{D_i}	Active/reactive demand at bus i .
$\overline{Q}_G / \underline{Q}_G$	Upper/lower reactive generation limits of unit i .
$\overline{SE}$	Maximum possible system emission.
$\overline{tp}_{ij} / \underline{tp}_{ij}$	Upper/lower limits of transformer tap at line ij .
$\overline{v}_i / \underline{v}_i$	Upper/lower limit of voltage at bus i .
τ	Carbon footprint tax to calculate excess carbon footprint surcharge.
κ	Cost of carbon emissions trading.
$\alpha_i, \beta_i, \gamma_i$	Emission coefficients of unit i .

C. Functions

$C_i(\cdot)$	Generation cost of unit i .
$Em_i(\cdot)$	Emission produced by unit i .
F^C	Economic-oriented objective function.
$f_{ij/ji}(\cdot)$	Power flow through line ij/ji .
$P_{G_i}^M(\cdot)$	Maximum active power of unit i , defined by the capability curve.

D. Variables

$CF_{G_g \rightarrow i/ij}$	Carbon footprint from unit g to bus i or line ij .
$ECF_{G_g \rightarrow i/ij}$	Energy consumption price from unit g to bus i or line ij .
Em^{defic}	Emissions deficit.
DCF_i	Demand carbon footprint at bus i .
$DCF_{G_g \rightarrow i}$	Contribution of unit g to the demand carbon footprint at bus i .
DCF_i^{exc}	Excess demand carbon footprint at bus i .
$DECP_{G_g \rightarrow i}$	Demand contribution of unit g to the energy consumption price at bus i .
$DECP_i$	Demand energy consumption price at bus i .
DCF_i^{sur}	Demand carbon footprint surcharge cost at bus i .

$GCD_{G_g \rightarrow i}$	Generators' contribution on demand at bus i .
SCF^{exc}	Excess system carbon footprint on generation side.
SCF^{sur}	System carbon footprint surcharge.
LCF_{ij}	Loss carbon footprint in line ij .
$LECP_{ij}$	Loss energy consumption price at line ij .
P_{G_i} / Q_{G_i}	Active/reactive power generation of unit i .
p_{ij} / p_{ji}	Direct/reverse active power flow of line ij .
$P_{G_g \rightarrow i}^{adj}$	Contribution of unit g on adjustment of demand i .
P_i^{adj}	Adjustment power of demand i .
$P_{G_g \rightarrow i}^T$	Traced power from unit g to bus i .
$\bar{P}_i$	Power entering bus i .
$\bar{P}_i^T$	Traced power entering bus i .
$\bar{P}_i^U$	Untraced power entering bus i .
Pr_i	Profit of generating unit i .
$Pr^\dagger$	Net profit on the generation side.
q_{ij} / q_{ji}	Direct/reverse reactive power flow through line ij .
tp_{ij}	Transformer tap of line ij .
$TPR_{G_g \rightarrow i}$	Traced power ratio from unit g to bus i .
UPR_{ji}	Untraced power ratio from bus j to bus i .
v_i	Voltage magnitude at bus i .
λ_i	Lagrange multipliers at bus i .
θ_{ij}	Voltage angle difference between buses i and j .

I. INTRODUCTION

THE progress and evolution of a country highly depends on electricity [1]. However, each technology used to generate electricity has undesired by-products such as emissions and other harmful environmental impacts [2].

To cope with climate change, it will be necessary to reduce global greenhouse gas (GHG) emissions up to 90% between 2040 and 2070 [3]. Among the primary energy sources used to generate electric power, coal is the cheapest and most popular in developing countries, where 41% of electricity comes from coal-fired power plants. On the other hand, coal accounts for 73% of GHG emissions in the electric power sector [4]. Therefore, this sector poses huge environmental concerns as a major source of carbon emissions and the future control of climate change will depend on the electric power generation policies [5]. In order to slow down this phenomenon, curbing GHG emissions is very important as well as establishing main targets and proposing appropriate tools for carbon emission abatement [6], [7].

Until now, most papers have focused on the generation side, where the technologies can be categorized as: i) CO₂ control devices, such as carbon capture and storage (CCS) [8], [9], ii) renewable-energy-based technologies (RET) [10], [11], iii) emission-constrained models (ECM) [12], [13], and iv) demand-response (DR) based models [14], [15]. The CCS technology is used to capture CO₂ from the power plant depositing it in a place where it is not able to enter the atmosphere. RETs are sources of energy with quasi-zero

emissions that are widely used to abate them. ECM models, by restricting generation from producing emissions, control emission levels and this usually results in a cost increase. In DR-based models the economic incentives result in a demand decrease and, consequently, emission reduction may be the result. Several countries, by using environmental-based policies aim at abating carbon emissions. The existing policies are Carbon Cap (CC), Cap and trade (C&D) and Carbon Tax (CT). In the CC and C&T models, a cap is a binding constraint that greatly affects the optimal dispatch and increases the total costs. Much of the cost of such limits is passed on to households. These are simply unfair policies that the costs associated with adapting such changes are borne by the consumers [16]. Therefore, such methods would reduce emissions while decreasing social welfare, by making the cost of energy much higher for the consumer [17]. Therefore, cap-based policies will raise the bills of all the consumers, even those with very low demands [18]. The other shortcoming of cap-based models is the free permits given to companies, which use energy intensively and are big polluters, where the vast majority of these valuable emission permits are awarded for free. The more an industry has been polluting, the more permits it will get. This way, these polluters and such industries, as well as the suppliers, made extra profits, because of raising the energy costs of consumers [19]. The carbon tax is an environmental tax that is levied on the carbon emitted to the atmosphere by the [20], [21]. However, the CT policy does not achieve a certain level of emissions reduction because: 1) emissions vary from year-to-year and 2) there are no clear incentives for the consumers and, above all, it raises the bill of all the consumers, even those with very low demands [18]. Neither CC-based policies nor the CT policy are capable of providing useful information for the consumers (carbon footprint, excess footprint, corresponding surcharge, etc.) and demand side management is done directly, that is, by using the CC, C&T and CT policies, all the consumers face a rise in their bills and they may decide to reduce the consumption. This shows the unfair nature of these policies in which the consumers with low demands (normally those in difficult financial situation) are charged as well, and this may release the burden of such surcharges from the shoulder of those consumers with high-energy consumption, which are the prime responsible for carbon emissions and put on the shoulder of low demands. In addition, a demand decrease negatively affects the net profit of those power plants that use these policies. This means that the more a demand decreases, the lower their profit becomes. Consequently, these methods cannot provide effective incentives to the generation side; on the contrary, there exists a deterrent that prevents them from encouraging the consumers to decrease their demands. It is true that emissions are a by-product of power generation; however, generation is driven by demand, hence, consumers should be considered as the prime responsible agents for carbon emissions.

In recent years, some actions have been adopted for consumers to reduce their energy consumption as well as carbon emissions, such as the UK Carbon Reduction Commitment Energy Efficiency Scheme, the Tokyo Emission

Trading Scheme, and the Perform Achieve Trade Scheme in India [22]. However, such obligations need to provide proper information to the demand side. The influence of a change on the generation or demand sides has been investigated via marginal carbon intensity [23], but it neither provides suitable information for the generation side nor for the demand side. In [24], two issues such as the carbon accounting at the regional level and locational carbon intensity assessment at the user level were addressed. It is assumed that the generators have the priority to supply the load at the same bus, and this is not always applicable, as more often than not the load at a bus may use the supply of adjacent units due to the system topology, operators' objectives, etc., [25]. In [5], a network-based model was proposed to accumulate the carbon emissions produced by various units on the demand side via the Proportional Sharing Theorem (PST) [26], [27], which is basically adequate for lossless systems. This approach works based on matrix operations that makes it inappropriate for large-scale networks since it requires the calculation of the inverse of large-scale sparse matrices. The same strategy was developed in [28] to quantify the carbon emission in multiple energy systems. In [29], a graph-based carbon emission tracing method was proposed. Although the paper addressed the main drawback of graph-based models (inapplicability for systems without loops), it uses the same assumption in [24] that makes it unsuitable in real systems.

None of the aforementioned works provides enough information for the demand side to manage carbon emissions. In comparison with existing methodologies, the contributions of this paper are threefold.

- 1) An improved PST model [30] as a tracing tool is used to provide useful information for the consumers, such as carbon footprint, excess carbon footprint (ECF), carbon footprint surcharge, energy consumption price, and hourly-based bill (before and after demand adjustment). Our tracing model, unlike [5] and [28], is not based on inverse matrix rules. The drawbacks in [24] and [29] are also addressed, in which the priority assumption (each unit has the priority to supply the load at the same bus) makes them overly simplified models inappropriate in the real world.
- 2) A demand adjustment process is proposed in which the consumers can adjust their demands by exchanging information with the utility side to eliminate carbon footprint surcharges.
- 3) A profit analysis on generation and demand sides is carried out; this analysis is used as an incentive for both sides.

The rest of this paper is organized as follows. Section II contains the proposed carbon footprint allocation and management. Case studies and results are presented in Section III. Section IV shows concluding remarks and future works.

II. CARBON FOOTPRINT MANAGEMENT

To manage the carbon footprint in power system, we should see the problem from the demand perspective. This paper proposes an allocation-based solution approach to handle this situation. It is worth mentioning that all the models have been implemented on AMPL and a commercial solver KNITRO has

Fig. 1. Flowchart of carbon footprint management.

Fig. 2. Flowchart of carbon footprint allocation.

been used to solve them.

A. Solution Approach

As can be seen from the carbon footprint management flowchart shown in Fig. 1, an optimal power flow (OPF) is used to minimize the total system cost. Then, the carbon footprint is allocated among the demands via an iterative process presented in Fig. 2. This process continues until all the powers from the generators are allocated to the demands and transmission losses. A detailed formulation of the allocation process is presented in subsection *b*. Then, the predefined carbon footprint limits (CFLs) of the demands are checked and in case that a CFL has been violated, the excess demand that yields the CFL violation is calculated by an adjustment process and the demand is adjusted. In this paper, the CFL violation check and the adjustment process is carried out by numerical order of demands instead of using a parallel adjustment or descending order of the demand carbon footprint (DCF). The parallel adjustment results in asking the consumers to decrease their demands much more than

necessary, while the adjustment in DCFs' decreasing order changes the power flow calculation. Since heavy loads are located in different places/areas of the system, it may result in more violations of the CFL of normal loads. If the DCF limit of demand i is violated, the adjustment process starts, otherwise the program continues until it checks the DCFs of all the demands. The adjustment process obtains the adjusted demands by using (40) and (41), see item 9 in subsection *A* and sub-subsection *b*, and these adjusted demands are updated in the OPF tool for recalculations. Due to peculiar structure of the emission function (in some situations, a decrease in generation may lead to increasing emissions), and the nonlinear and nonconvex nature of the OPF (running the OPF after adjusting a demand may lead to a different dispatch), the adjustment or readjustment of a demand may occur, then, the readjustment process is performed again. Note that the CFL, similar to the cap size of the polluters, is defined using several parallel analyses such as weather conditions, emission concentrations, etc. The management process is explained as follows.

a. Power flow calculation

The main concern from the generation standpoint is to minimize the generation cost while satisfying the constraints. To have a more realistic model, an active-reactive OPF (AROPF) method is used considering the capability curve [31].

$$\min_{\substack{P_{G_i}, Q_{G_i}, v_i, p_{ij}, p_{ji}, \\ q_{ij}, \theta_{ij}, tp_{ij}, P_{G_i}^M}} F^C = \sum_{i \in \Omega_G} C_i(P_{G_i}) \quad (1)$$

s.t.

$$P_{G_i} - P_{D_i} - g_i^{sh} v_i^2 - \sum_{ij \in \Omega_l} p_{ij} - \sum_{ji \in \Omega_l} p_{ji} = 0; \forall i \in \Omega_b \quad (2)$$

$$Q_{G_i} - Q_{D_i} + b_i^{sh} v_i^2 - \sum_{ij \in \Omega_l} q_{ij} - \sum_{ji \in \Omega_l} q_{ji} = 0; \forall i \in \Omega_b \quad (3)$$

$$|f_{l_{ij}}(v, \theta, tp)| \leq \overline{f_{l_{ij}}}; \forall ij \in \Omega_l \quad (4)$$

$$\underline{v}_i \leq v_i \leq \overline{v}_i; \forall i \in \Omega_b \quad (5)$$

$$\underline{P}_{G_i} \leq P_{G_i} \leq P_{G_i}^M(Q_{G_i}); \forall i \in \Omega_G \quad (6)$$

$$\underline{Q}_{G_i} \leq Q_{G_i} \leq \overline{Q}_{G_i}; \forall i \in \Omega_G \quad (7)$$

$$\underline{tp}_{ij} \leq tp_{ij} \leq \overline{tp}_{ij}; \forall ij \in \Omega_l \quad (8)$$

The fuel cost of unit i is approximated by a quadratic function of the active power in (9), [32]. The upper limit of the active generation in (6) is obtained from the capability curve. The interested readers may refer to [31] for details.

$$C_i(P_{G_i}) = a_i(P_{G_i})^2 + b_i P_{G_i} + c_i; \forall i \in \Omega_G \quad (9)$$

As for the cost function, the emission function of unit i is approximated by a quadratic function in (10), [21].

$$Em_i(P_{G_i}) = \alpha_i(P_{G_i})^2 + \beta_i P_{G_i} + \gamma_i; \forall i \in \Omega_G \quad (10)$$

Note that the emission limit on the generation side (11) is considered in the OPF problem [33]. However, its main drawback is the cost that may be incurred by the demand. Therefore, in this paper, this is disregarded and, in case of an

Fig. 3. Transmission line flow.

emission excess, a surcharge cost is paid by the producers. See Section II, subsection D.

$$\sum_{i \in \Omega_G} Em_i(P_{G_i}) \leq \overline{SE} \quad (11)$$

b. Carbon footprint and price allocation

After performing the power flow calculation and using the units' output power, transmission losses, and transmission line flows, the carbon footprint is allocated among the demands. Thus, a tracing-based allocation approach that can be seen in Fig. 2 is used. The basic concepts and the procedure are explained as follows.

1) Bus Absorbed Power (BAP)

The BAP is the amount of active power absorbed by bus i , $\bar{P}_i$. This power consists of the input power flow to bus i from an adjacent bus j , p_{ji} , and the power generated at bus i , P_{G_i} , (12).

$$\bar{P}_i = \sum_{ji \in \Omega_l} (p_{ji} - P_{ji}^L) + P_{G_i} = \sum_{ji \in \Omega_l} (-p_{ij}) + P_{G_i}; \forall i \in \Omega_b, p_{ji} > 0 \quad (12)$$

where P_{ji}^L stands for the transmission loss at line ji .

As shown in Fig. 3, $p_{ji} > 0$ guarantees that bus i is receiving power from bus j , however, the power sent from bus j , as a result of transmission loss, will not be received completely at bus i . Therefore, transmission loss must be subtracted from it. As can be seen from Eq. (12), instead of taking into account $p_{ji} - P_{ji}^L$, the equivalent term p_{ij} can be used. The transmission loss of line ij is obtained as follows:

$$P_{ij}^L = |p_{ij} - p_{ji}|; \forall ij \in \Omega_l \quad (13)$$

On the other hand, the BAP at bus i is split into two terms, traced power, $\bar{P}_i^T$, and untraced power, $\bar{P}_i^U$, in (14).

$$\bar{P}_i = \bar{P}_i^T + \bar{P}_i^U; \forall i \in \Omega_b \quad (14)$$

2) Bus Traced Power (BTP)

The BTR is the traced active power produced by unit g and absorbed by bus i . Note that, initially, only the output power of committed units at bus i , P_{G_i} , can be traced.

$$\bar{P}_i^{U(1)} = \sum_{g \in \Omega_G / g=i} P_{G_g}; \forall i \in \Omega_b \quad (15)$$

3) Bus Untraced Power (BUP)

The BUP is the untraced active power absorbed by bus i . Note that, initially, all power coming from the adjacent buses is untraced.

$$\bar{P}_i^{U(1)} = \sum_{ji \in \Omega_l} (p_{ji} - P_{ji}^L); \forall i \in \Omega_b, p_{ji} > 0 \quad (16)$$

At each iteration, a part of the untraced power is traced. In order to find out the traced power at each bus i , the generating unit contribution (GUC) to this bus, $\bar{P}_{G \rightarrow i}^T$, is used, (17), and the untraced power is defined in (18).

$$\bar{P}_i^T = \sum_{g \in \Omega_G} P_{G_g \rightarrow i}^T; \forall i \in \Omega_b \quad (17)$$

$$\bar{P}_i^U = \sum_{ji \in \Omega_i} (p_{ji} - P_{ji}^L); \forall i \in \Omega_b, p_{ji} > 0 \quad (18)$$

To start the tracing process, two ratios, namely traced and untraced ratios, are defined.

4) Traced and Untraced Power Ratios

In order to trace the untraced power, two auxiliary ratios, traced power ratio (TPR) for traced power from unit g to bus i , and untraced power ratio (UPR) for untraced power from bus j to bus i are used, as shown in (19) and (20), respectively.

$$TPR_{G_g \rightarrow i} = \frac{P_{G_g \rightarrow i}^T}{\bar{P}_i}; \forall i \in \Omega_b, g \in \Omega_G \quad (19)$$

$$UPR_{j \rightarrow i} = \frac{p_{ji} - P_{ji}^L}{\bar{P}_i} = \frac{-p_{ij}}{\bar{P}_i}; \forall ji \in \Omega_i, p_{ji} > 0 \quad (20)$$

Since initially only the traced powers at the generation buses are known, the corresponding initial TPR is calculated in (21), while the UPR is calculated via (20) as (22).

$$TPR_{G_g \rightarrow i}^{(1)} = \frac{P_{G_g}^T}{\bar{P}_i}; \forall i \in \Omega_b, g \in \Omega_G, g = i \quad (21)$$

$$UPR_{j \rightarrow i}^{(1)} = \frac{-p_{ij}}{\bar{P}_i}; \forall ji \in \Omega_i, p_{ji} > 0 \quad (22)$$

According to the PST rule, the ratio of the input power at bus j is equal to the ratio of the constituent components of p_{ji} . Consequently, via a distribution process, $UPR_{j \rightarrow i}$ can be taken away, by adjusting it to zero, and distributing it over $\bar{P}_j$ according to the component ratio of $\bar{P}_i$ using (23) and (24). In (23), the UPR at iteration $k+1$ from each bus h to bus i is equal to the UPR at the previous iteration k plus the UPR from bus h to j (for each bus h adjacent to i) multiplied by the UPR from bus j to bus i . It is worth mentioning that this distribution is done if there is any bus h that satisfies $UPR_{h \rightarrow j} \geq 0$. In (24), the TPR at iteration $k+1$ from each generating unit g to bus i is equal to the TPR at the previous iteration k plus the TPR from unit g to bus j multiplied by the UPR from bus j to bus i ; however, the distribution is done if there is any bus m that satisfies $TPR_{m \rightarrow j} \geq 0$. Note that, to take away $UPR_{h \rightarrow j}$ in a power system without loops, this value is set to zero, otherwise a small value, ε , is assigned.

$$UPR_{h \rightarrow i}^{(k+1)} = UPR_{h \rightarrow i}^{(k)} + UPR_{h \rightarrow j}^{(k)} \cdot UPR_{j \rightarrow i}^{(k)}; \forall hj \in \Omega_i, h \neq j \quad (23)$$

$$TPR_{G_g \rightarrow i}^{(k+1)} = TPR_{G_g \rightarrow i}^{(k)} + TPR_{G_g \rightarrow j}^{(k)} \cdot UPR_{j \rightarrow i}^{(k)}; \forall g \in \Omega_G, i \in \Omega_b, g \neq j \quad (24)$$

The other elements that are not involved in the distribution process of bus i remain unchanged.

$$TPR_{G_g \rightarrow n}^{(k+1)} = TPR_{G_g \rightarrow n}^{(k)}; \forall j \in \Omega_b, \forall n \in \Omega_b, n \neq i \quad (25)$$

$$UPR_{j \rightarrow n}^{(k+1)} = UPR_{j \rightarrow n}^{(k)}; \forall jn \in \Omega_i, n \neq i \quad (26)$$

The distribution process is terminated when all the untraced elements, $UPR_{j \rightarrow i}$ are taken away by repeating (23) and (24). The stopping criterion is as follows:

$$UPR_{j \rightarrow i} \leq \varepsilon; \forall ji \in \Omega_i \quad (27)$$

Interested readers may refer to [34] for more details via a didactic example.

5) Generators' Contribution on Demand (GCD), Demand Energy Consumption Price (DECP) and Demand Carbon Footprint (DCF)

DECP and DCF are the price of the consumed energy and the corresponding carbon emitted to the atmosphere, respectively. After tracing the power at each bus, the carbon footprint is allocated among the demands. The contributions of unit g to calculate DECP and DCF are shown in (28) and (29), respectively, while the total DECP and DCF values of demand i are shown in (31) and (32), respectively.

$$DECP_{G_g \rightarrow i} = \lambda_g \cdot P_{G_g} \cdot \frac{TPR_{G_g \rightarrow i}}{P_{G_g}} \cdot P_{D_i}; \forall g \in \Omega_g, \forall i \in \Omega_D \quad (28)$$

$$DCF_{G_g \rightarrow i} = Em_g(P_{G_g}) \cdot \frac{TPR_{G_g \rightarrow i}}{P_{G_g}} \cdot P_{D_i}; \forall g \in \Omega_g, \forall i \in \Omega_D \quad (29)$$

$$GCD_{G_g \rightarrow i} = TPR_{G_g \rightarrow i} \cdot P_{D_i}; \forall g \in \Omega_g, \forall i \in \Omega_D \quad (30)$$

$$DECP_i = \sum_{g \in \Omega_G} DECP_{G_g \rightarrow i}, \forall i \in \Omega_D \quad (31)$$

$$DCF_i = \sum_{g \in \Omega_G} DCF_{G_g \rightarrow i}, \forall i \in \Omega_D \quad (32)$$

6) Loss Energy Consumption Price (LECP) and Loss Carbon Footprint (LCF)

LECP and LCF are the price of consumed energy due to transmission loss and the corresponding carbon emitted to the atmosphere, respectively. The contributions of unit g to calculate LECP and LCF are presented in (33) and (34), respectively, while the total LECP and LCF of demand i are obtained in (35) and (36).

$$LECP_{ij(G_g \rightarrow i)} = \lambda_g \cdot P_{G_g} \cdot \frac{TPR_{G_g \rightarrow i}}{P_{G_g}} \cdot |p_{ij} - p_{ji}|; \forall g \in \Omega_G, p_{ij} > 0 \quad (33)$$

$$LCF_{ij(G_g \rightarrow i)} = E_g(P_{G_g}) \cdot \frac{TPR_{G_g \rightarrow i}}{P_{G_g}} \cdot |p_{ij} - p_{ji}|; \forall g \in \Omega_G, p_{ij} > 0 \quad (34)$$

$$LECP_{ij} = \sum_{g \in \Omega_G} LECP_{ij(G_g \rightarrow i)}; p_{ij} > 0 \quad (35)$$

$$LCF_{ij} = \sum_{g \in \Omega_G} LCF_{ij(G_g \rightarrow i)}; p_{ij} > 0 \quad (36)$$

c. Demand side management

After the allocating process is done, each demand can observe its energy consumption price, carbon footprint, excess carbon footprint (ECF), and carbon tax. Providing useful information to the consumers about how much of a reduction in their demand may result in tax exemption and bill savings is used as an incentive. However, demand adjustment to eliminate the ECF on the demand side is a complicated task. The adjustment procedure is explained in detail as follows.

1) Excess Demand Carbon Footprint and Surcharge

In order to control the carbon footprint from the demand side, first, a predefined threshold for the demands is considered. If the threshold is reached, the demands receive a surcharge corresponding with the ECF. Carbon surcharges offer a potentially cost-effective tool for carbon footprint

reduction. The ECF of a demand and its incurred surcharge tax are calculated in (37) and (38), respectively. Note that the carbon footprint tax, τ , is defined, see the European Union Emission Trading System [35].

$$DCF_i^{exc} = DCF_i - \overline{DCF_i}, \forall i \in \Omega_D \quad (37)$$

$$DCF_i^{sur} = DCF_i^{exc} \cdot \tau, \forall i \in \Omega_D, DCF_i^{exc} > 0 \quad (38)$$

2) Finding the Contribution of Each Unit to the Excess Carbon Footprint (ECF)

By using the traced power ratios in (19) and the demand ECFs, the contribution of each unit to the ECF is obtained in (39).

$$DCF_{G_g \rightarrow i}^{exc} = \frac{DCF_{G_g \rightarrow i}}{DCF_i} \cdot DCF_i^{exc}, \forall g \in \Omega_G, \forall i \in \Omega_D \quad (39)$$

3) Demand Adjustment

To approximate the adjustment of the demand, each unit's generation is modified and this adjustment is transferred to the demand side. Due to contribution theory and considering loss reduction (as a consequence of generation reduction), ECF reduction is guaranteed. By using (40) and (41), the contribution of each unit to the demand adjustment and total demand adjustment is obtained.

$$\frac{P_{G_g \rightarrow i} - P_{G_g \rightarrow i}^{adj}}{P_{G_g} - P_{G_g \rightarrow i}^{adj}} (Em_g(P_{G_g}) - DCF_{G_g \rightarrow i}^{exc}) = DCF_{G_g \rightarrow i} - DCF_{G_g \rightarrow i}^{exc}, \forall i \in \Omega_D \quad (40)$$

$$P_{d_i}^{adj} = \sum_{g \in \Omega_G} P_{G_g \rightarrow i}^{adj}, \forall i \in \Omega_D \quad (41)$$

B. Demand Side Benefit Analysis

The consumers may only reduce their demands if there is an incentive such as eliminating the incurred ECF tax and lowering the energy usage bill. Hence, the demand energy bill (DEB), before and after adjustment, is provided for the consumers. This payment is calculated in (42).

$$DEB_i = DECP_i + DCF_i^{sur}, \forall i \in \Omega_D \quad (42)$$

C. Generation Side Profit Analysis

Demand side management disregarding the profit on the generation side does not reveal the advantages and drawbacks of the management system. Therefore, a profit analysis for the generation side is performed.

By solving (1)–(8), the vector of marginal prices, λ , is formed by the Lagrange multipliers associated with the active power balance in (2). Finding the Lagrange multipliers in a linear system is an easy task; however, in order to find these multipliers in a nonlinear model, an iterative process is used. At each iteration, the demand at a bus is increased by 1 MW and the difference between the optimal solutions before and after that 1 MW increase produces the Lagrange multiplier at that bus [36]. Using the marginal prices at generating bus g , the generator's profit is obtained in (43), [37].

$$Pr_g = \lambda_g P_{G_g} - C_g(P_{G_g}) \quad (43)$$

The excess system carbon emissions (44) and the corresponding surcharges (45) should be considered to calculate the net profit on the generation side, as shown in (46).

$$SCF^{exc} = \sum_{g \in \Omega_G} Em_g(P_{G_g}) - \overline{SE} \quad (44)$$

$$SCF^{sur} = SCF^{exc} \cdot \tau, \forall SCF^{exc} > 0 \quad (45)$$

$$Pr^{\dagger} = \sum_{i \in \Omega_G} (\lambda_i P_{G_i} - C_i(P_{G_i})) - SCF^{sur} \quad (46)$$

III. CASE STUDIES AND RESULTS

In this section, two case studies are presented: a 5-bus system and the IEEE 118-bus system. The proposed model is implemented on AMPL and solved via the KNITRO solver on a Windows-based workstation with two processors clocking at 3.3 GHz and 8 GB RAM. The carbon tax for excess carbon emissions on both generation and demand sides is \$23/ton [38].

A. 5-Bus System

This system consists of 7 transmission lines, 3 generating units (G1, G2, and G5), and 3 demand buses (L2, L3, and L4) with a total demand of 320 MW, where data comes from [33].

Fig. 4. 5-bus test system without line flow limits.

TABLE I
CARBON FOOTPRINT ALLOCATION (ton/h) AND GUC (MW)

Demand		Generating Units						Carbon Footprint (ton/h)
		G1		G2		G5		
		GUC	$CF_{Gg \rightarrow i/j}$	GUC	$CF_{Gg \rightarrow i/j}$	GUC	$CF_{Gg \rightarrow i/j}$	
L2		14.267	12.048	7.678	16.574	43.055	58.580	87.202
L3		73.268	61.872	6.896	14.885	84.836	115.428	192.185
L4		0.0	0.0	0.0	0.0	90.00	122.454	122.454
Loss (MW)	1-2	0.246	0.208	0.0	0.0	0.0	0.0	0.208
	1-3	0.459	0.388	0.0	0.0	0.0	0.0	0.388
	2-3	0.023	0.019	0.012	0.026	0.069	0.094	0.139
	2-4	0.0	0.0	0.0	0.0	0.162	0.220	0.220
	2-5	0.0	0.0	0.0	0.0	0.198	0.269	0.269
	3-5	0.0	0.0	0.0	0.0	0.352	0.479	0.479
	4-5	0.0	0.0	0.0	0.0	0.353	0.481	0.481
Total		88.263	74.535	14.586	31.485	219.025	298.005	404.025

1) Case 1: Without Line Flow Limits

This case is used to provide the results of the allocation process and the GUC on carbon footprint, loss, and energy consumption price, and also to explain the adjustment process in detail. CFL values for L2, L3, and L4 are 100, 180, and 120 ton/h, respectively, while the desired system emission limit is 385 ton/h. To validate the approach, the active and reactive power flows are provided in Fig. 4.

Table I shows the GUC of unit g to satisfy the demands at bus i and transmission losses at branch ij , $CF_{Gg \rightarrow i/j}$, to calculate the corresponding carbon footprint. It can be seen that there is a 12.185 ton/h and a 2.454 ton/h violation of the

CFLs for L3 and L4, respectively. Therefore, the operator may manage them by providing enough information, warnings, and incentives for these demands. The warnings are the current DCF, DECP, ECF, and DCF surcharge values. The incentives are the demand adjustment results, such as money savings in the electricity bill by lowering the demand and the elimination of the ECF surcharge. After providing such information, the adjustment process is taken into account, which is explained in detail using demand L3, as follows.

Table II shows the information provided for the consumers as well as total power savings (TPS), demand carbon footprint change (DCFC), and total cost savings (TCS). Such information is used to encourage the consumers to manage their demands.

From (37) and (38), the ECF and the surcharge of L3 are 12.185 ton/h and \$280.26/h, respectively, as seen in Table II. From Table I and using (39), the contributions of G1, G2, and G5 to ECF are obtained: 3.923, 0.944, and 7.318 ton/h, and using (40), the contribution of these units to the demand adjustment are 4.645, 0.437, and 5.379 MW, respectively.

TABLE II
INFORMATION PROVIDED TO DEMANDS, BEFORE AND AFTER ADJUSTMENT—
WITHOUT FLOW LIMITS FOR THE 5-BUS SYSTEM, CASE 1

Information provided	L2		L3		L4	
	Before	After	Before	After	Before	After
Demand (MW)	65.0	65.0	165.0	154.539	90.0	88.997
DCF (ton/h)	87.202	87.646	192.185	178.750	122.454	119.885
DCF ^{exc} (ton/h)	0.0	0.0	12.185	0.0	2.454	0.0
DCF ^{sur} (\$/h)	0.0	0.0	280.26	0.0	56.44	0.0
DECP (\$/h)	2,725.65	2,712.35	6,908.34	6,440.96	3,772.15	3,711.20
DEB (\$/h)	2,725.65	2,712.35	7,188.60	6,440.96	3,828.59	3,711.20
TPS (MW/h)	0.0		10.461		1.003	
DCFC (ton/h)	0.444		-13.435		-2.569	
TCS (\$/h)	13.30		747.64		117.39	

TABLE III
DEMAND ADJUSTMENT PROCEDURE STEPS FOR THE 5-BUS SYSTEM, CASE 1

Adj. Step	L2			L3			L4		
	P _b	DCF	DECP	P _b	DCF	DECP	P _b	DCF	DECP
S1: —	65.0	87.202	2725.6	165.0	192.185	6908.3	90.0	122.454	3772.1
S2: L3	65.0	87.595	2713.6	154.539	178.673	6443.6	90.0	121.352	3754.8
S3: L4	65.0	87.646	2712.3	154.539	178.75	6441.0	88.997	119.885	3711.2

Hence, from (41), a total decrease of 10.461 MW in L3 is required to keep carbon emissions less than or equal to the predefined value. The same process is applied to adjust L4.

Before the adjustment, demands L3 and L4 face carbon tax surcharge costs of \$280.26/h and \$56.44/h, respectively, corresponding to ECF values of 12.185 and 2.454 ton/h. By providing adjustment signals to the consumers and letting them know the advantages of these adjustments, the demands can be managed. It can be seen that, by decreasing the demands L3 and L4 by 10.461 MW and 1.003 MW, respectively, the CFLs are no longer violated. Consequently, via this adjustment, not only the DECPs decrease but also the surcharge taxes are eliminated. For example, for L3, the consumers may save \$747.64/h by decreasing their demand by 10.461 MW. For L2, the demand adjustment at critical buses 3 and 4 may alter the economic operation, affecting DCF values negatively. To explain this, the sequential procedure of load adjustments is provided in Table III.

Since the system should be operated economically, the adjustment of a demand may affect other demands positively or negatively. The first step in Table III (S1) shows the loads

before adjustments, where the second (S2) and third (S3) steps are related to the adjustments of L3 and L4, respectively. In S2, after adjusting L3 to 154.539 MW, the DECPs of L2 and L4 decrease by \$12.0/h and \$17.3/h, respectively. This adjustment has a negative effect on the DCF of L2, showing an increase of 0.393 ton/h, which has a positive effect on the DCF of L4 at the same time, with a decrease of 1.102 ton/h. Such effects are seen in the third step as well, where, after adjusting L4 to 88.997 MW, the DECPs of L2 and L3 decrease by \$1.3/h and \$2.6/h, but this negatively affects the DCFs of both loads, with increases of 0.052 ton/h and 0.077 ton/h, respectively. This is due to the nonconvex characteristic of the emission function that may have a positive effect in some cases and a negative effect in others. However, for L2, which does not require an adjustment, the DECP decreases by \$13.3/h corresponding with a DCF increase of 0.444 ton/h. Note that, in this case, such an increase in the DCF of L2 does not result in a violation of its CFL. However, if the adjustment of the demands results in a violation of the CFL of other demands, the corresponding demands are adjusted/readjusted to eliminate the violation. This situation is explained by using the 5-bus system with transmission line limits.

TABLE IV
PROFIT, EXCESS CARBON FOOTPRINT AND SYSTEM NET PROFIT FOR THE 5-BUS SYSTEM BEFORE AND AFTER ADJUSTMENT, CASE 1

		Before adjustment	After adjustment
Profit (\$/h)	G1	75.589	61.862
	G2	14.164	11.123
	G5	2395.855	2349.483
	Total	2485.608	2422.468
Carbon footprint	SCF ^{exc} (ton/h)	19.025	3.302
	SCF ^{sur} (\$/h)	437.575	75.946
Net Profit (\$/h)		2048.033	2346.522

The total emissions for steps S1, S2, and S3 are 404.025 ton/h (401.841 ton/h of DCF and 2.184 ton/h of LCF), 389.645 ton/h (387.620 ton/h of DCF and 2.025 ton/h of LCF), and 388.302 ton/h (386.281 ton/h of DCF and 2.021 ton/h of LCF), respectively. It can be seen that, by managing the loads at each step, total emissions decrease. Table IV shows the effects of this decrease on the generation side.

Table IV presents some useful information on the generation side, before and after the demand adjustment process, such as the profit of each unit and the total profit, carbon footprint (the generation side excess footprint, SCF^{exc} , and its incurred surcharge cost, SCF^{sur}), and the generation side net profit. As it can be seen, the profit of units G1, G2, and G5 after demand adjustment decreases by \$13.727/h, \$3.041/h, and \$46.372/h, and, consequently, the total profits of the units decrease by \$63.14/h. At first glance, it may seem that this adjustment negatively affects the profit on the generation side and, therefore, which incentive should the producers be willing to accept? Before the adjustment, an ECF of 19.025 ton/h causes a surcharge cost of \$437.575/h. Therefore, the net profit on the generation side before the adjustment is \$2048.033/h. After demand adjustment, the carbon footprint on the generation side is reduced so that the surcharge is decreased. This shows that, although the profits for the generating units decrease, the generation net profit increases by \$298.489/h, which is an effective incentive.

Fig. 5. Line flows of the 5-bus system before and after the adjustment, case 2.

TABLE V
INFORMATION PROVIDED FOR DEMANDS, BEFORE AND AFTER ADJUSTMENT
FOR THE 5-BUS SYSTEM, CASE 2

Provided Information	L2		L3		L4	
	Before	After	Before	After	Before	After
Demand (MW)	65.0	65.0	165.0	158.758	90.0	87.555
DCF (ton/h)	82.477	84.922	185.460	179.879	117.323	114.951
DCF ^{exc} (ton/h)	0.0	0.0	5.460	0.0	2.323	0.0
DCF ^{sur} (\$/h)	0.0	0.0	125.58	0.0	53.43	0.0
DECP (\$/h)	2699.59	2695.43	6854.75	6587.94	3694.86	3607.35
Total Cost (\$/h)	2699.59	2695.43	6980.33	6587.94	3748.29	3607.35
TPS (MW/h)	0.0		6.242		2.445	
DCFC (ton/h)	2.445		-5.581		-2.372	
TMS (\$/h)	25.34		398.78		121.63	

TABLE VI
DEMAND ADJUSTMENT PROCEDURE FOR THE 5-BUS SYSTEM, CASE 2

Process	L2			L3			L4		
	P _D	DCF	DECP	P _D	DCF	DECP	P _D	DCF	DECP
S1: —	65.0	82.477	2699.6	165.0	185.460	6854.8	90.0	117.323	3694.9
S2: L3	65.0	83.695	2691.4	160.0644	179.988	6637.4	90.0	117.039	3690.3
S3: L4	65.0	84.822	2696.5	160.0644	181.481	6644.8	87.5547	115.00	3608.1
S4: L3	65.0	84.922	2695.4	158.7578	179.879	6587.9	87.5547	114.951	3607.3

2) Case 2: With Line Flow Limits

This case is used to explain the situations in which the adjustment of the demand results in a violation of the CFL of other demands. In this case, the CFL values of demands at buses 2, 3, and 4 are 100, 180, and 115 ton/h, respectively, while the system emission limit is the same as in case 1. The active power flow limits in branches 1-2 and 4-5 are 29 MW and 137 MW, respectively.

Fig. 5 shows the active power flows, before and after the adjustment. It can be deduced that the adjustment may increase the system's degree of freedom, e.g. before the adjustment the limit of line 1-2 is reached, while, after the adjustment, the flow is 1.95 MW lower than the limit.

Table V shows the information provided for the demands in case 2 of the 5-bus system. First, the ECFs of L3 and L4 are 5.46 ton/h and 2.323 ton/h, corresponding to surcharges of \$125.58/h and \$53.43/h, respectively. However, after adjusting L3 and L4 to 158.758 MW and 87.555 MW, respectively, these demands not only address the carbon footprint violation, but also the carbon surcharge tax is also eliminated.

It can be seen from Table V that there is a 6.242 MW decrease in L2 that saves \$392.39/h (\$125.58/h from surcharge elimination and \$266.81/h from load decrease) and

a 2.445 MW decrease in L4 that saves \$140.94/h (\$53.43/h from surcharge elimination and \$87.51/h from load decrease). The required readjustment procedure is shown in Table VI and, finally, the carbon footprints of L3 and L4 are below their CFLs, 179.879 and 114.951 ton/h, respectively.

As seen in Table VI, in S2, L3 is adjusted to 160.0644 MW (a 4.9357 MW decrease) and the CFL is satisfied by decreasing the DCF to 179.988 ton/h. This adjustment results in a carbon footprint decrease in L4 of 0.284 ton/h and an increase in L2 of 1.218 ton/h. However, in S3, L4 is adjusted to 87.5547 MW (a 2.4453 MW decrease) to eliminate the violation of the CFL (2.039 ton/h). Although this adjustment results in an increase of the DECPs of L2 and L3 of \$5.1/h and \$8.4/h, respectively, it still brings some economic benefits to them, compared with S1, by decreasing DECPs by \$3.1/h and \$210.0/h. However, the carbon footprints of L2 and L3 increase by 1.127 ton/h and 1.493 ton/h, and, consequently, this results in a violation at L3 of 1.481 ton/h. Finally, in S4, the demand is readjusted to 158.7578 MW to satisfy the CFL and this adjustment does not yield any violation. By comparing Table VI (with two adjustments and one readjustment) with Table III (with only two adjustments), the effects of system topology on the convergence of the proposed model is revealed. That is, the more limited the system is, the lower the degree of freedom and, consequently, running the OPF after the adjustment process may result in new violations of this recently-adjusted demand or other demands.

Table VII presents useful information for the generation side. It can be seen that, after the adjustment of the demands, the profits of G1 and G2 decrease by \$12.814/h and \$9.779/h, respectively, while the profit of G5 increases by \$31.073/h.

TABLE VII
PROFIT, CARBON FOOTPRINT, AND SYSTEM NET PROFIT, BEFORE AND AFTER ADJUSTMENT FOR THE 5-BUS SYSTEM, CASE 2

		Before adjustment	After adjustment
Profit (\$/h)	G1	85.780	72.966
	G2	24.654	14.875
	G5	2211.349	2242.422
	Total	2321.783	2330.263
Carbon footprint	SCF ^{exc} (ton/h)	2.345	0.0
	SCF ^{sur} (\$/h)	53.935	0.0
Net Profit (\$/h)		2267.848	2330.263

Total system emissions obtained from running the OPF before adjustment are 387.345 ton/h, showing an excess emission of 2.345 ton/h, with a surcharge of \$53.935/h. However, this surcharge is eliminated after the adjustment and the net profit increases by \$62.415/h.

B. IEEE 118-Bus System

This system contains 10 demands with CFLs set at buses 59, 70, 74, 75, 76, 77, 78, 90, 92, and 116 with 310, 210, 170, 150, 150, 190, 220, 400, 160, 450 ton/h, respectively. The data of this system is retrieved from [39].

Table VIII presents the carbon footprint of each demand, initially and after adjustment. Each row presents Sx: Bus# (AD), where Sx (x is an integer) is the step counter, Bus # is the bus whose demand must be adjusted, and (AD) is the adjusted demand in MW. It can be seen that all the CFLs have been violated initially. Therefore, all the corresponding demands need to be adjusted.

TABLE VIII

DEMAND ADJUSTMENT PROCEDURE FOR THE IEEE 118-BUS SYSTEM

Bus #	59	70	74	75	76	77	78	90	92	116
S1: —	315.6	211.9	170.8	150.1	153.9	190.2	220.2	417.7	166.6	494.4
S2: 59 (272.1)	309.0	211.8	171.3	149.9	154.5	190.1	220.1	417.6	166.5	492.3
S3: 70 (65.4)	309.0	209.9	171.6	149.9	154.5	190.1	220.1	417.6	166.5	492.4
S4: 74 (63.9)	308.9	209.9	164.6	149.8	156.0	189.9	219.9	417.5	166.5	493.2
S5: 76 (63.8)	308.9	209.8	166.2	149.8	150.0	189.9	219.9	417.4	166.4	493.9
S6: 90 (156.2)	308.9	209.7	166.8	149.7	150.8	189.7	219.7	397.8	165.5	495.2
S7: 92 (62.8)	308.9	209.7	167.0	149.7	151.0	189.7	219.7	397.2	159.8	495.6
S8: 116 (165.9)	308.5	208.9	170.3	149.1	153.8	189.1	218.9	396.6	159.5	450.0
S9: 74 (62.1)	308.5	208.9	167.3	149.1	154.3	189.1	218.9	396.6	159.5	450.3
S10: 76 (60.6)	308.4	208.8	168.6	149.0	150.0	189.0	218.8	396.5	159.5	450.9
S11: 116 (165.9)	308.4	208.8	168.6	149.0	150.1	189.0	218.8	396.5	159.5	450.0
S12: 76 (60.5)	308.4	208.8	168.7	149.1	150.0	189.0	218.8	396.5	159.5	450.1
S13: 116 (165.5)	308.4	208.8	168.7	149.1	150.0	189.0	218.8	396.5	159.5	450.0

In some steps, S2 and S4, the adjustment of demands 59 and 74 satisfies the carbon footprint of other demands such as 75, 77, and 78, while in some steps, such as S6 and S8-S12, the adjustments result in a violation of the carbon footprint of other demands and, consequently, the readjustment process is applied. Note that boldface values represent violations of the carbon footprints in Table VIII. On the other hand, those consumers located in critical regions or the ones that must decrease a noticeable fraction of their demands, may incur in a violation after adjustment and running of the OPF. This situation can be observed in demand 116 at step 8 (S8). In order to consider the adjustment/readjustment procedure of this demand in detail, the generating units' contribution and the corresponding carbon footprints before adjustment, S7, and during the adjustment process are reported in Table IX. As can be seen from this table, the adjustment of demand 116 is done in five iterations. Considering S7 shows a DCF limit violation of demand 116 with 45.5798 ton/h of excess emissions. In S8(1), the adjustment process asks the consumers for a decrease of 16.9230 MW to satisfy the DCF limit. However, after this demand decrease, when running the OPF, the optimal dispatch and, consequently, the unit contributions are changed and this results in a smaller DCF limit violation, with excess emissions of 3.0219 ton/h. In S8(2), to address this violation, a decrease of 1.1145 MW is requested and managed but, again, after running an OPF, a smaller violation than the previous violation in DCF limit results. Eventually, at S8(5) the readjustment process satisfies the DCF limit at this bus. However, this causes a violation of the DCF at bus 74, which is addressed at S9. This process continues until all DCF limits are satisfied. Since, in this system, load buses 70, 74, 76, 90, 92, and 116 are located in the same region, running the OPF after adjusting one of these demands may result in a new violation of the recently-adjusted demand or other demands.

Table X shows that there are initial carbon footprint violations of 91.4 ton/h and 648.9 ton/h on the demand and generation sides, respectively, which cause surcharges of \$2,102.2/h and \$14,924.7/h. However, after applying the proposed approach, the consumers decrease their demands by 46.4 MW/h resulting in a significant decrease of their energy bills of \$4,225.9/h. Although this decrease does not totally eliminate the carbon footprint surcharge on the generation side, it positively affects the net profit, increasing it by \$3,233.2/h, compared with the case before adjustment.

TABLE IX

CARBON FOOTPRINT ALLOCATION (ton/h) AND GUC (MW) OF DEMAND AT BUS 116 DURING THE ADJUSTMENT/READJUSTMENT (Adj/Readj) PROCESS

Adj/ Readj	Generating Units								DCF
	G65		G66		G69		G80		
	GUC	$CF_{Gg \rightarrow i}$	GUC	$CF_{Gg \rightarrow i}$	GUC	$CF_{Gg \rightarrow i}$	GUC	$CF_{Gg \rightarrow i}$	
S7	57.4908	95.4988	2.8073	5.6681	110.4498	353.9039	13.2522	40.5090	495.5798
S8 (1)	49.8659	82.5888	2.0793	4.1864	105.5874	337.1559	9.5445	29.0908	453.0219
S8 (2)	49.3601	81.7352	2.0350	4.0964	105.2672	336.0569	9.3003	28.3412	450.2297
S8 (3)	49.3217	81.6703	2.0316	4.0896	105.2429	335.9735	9.2817	28.2842	450.0176
S8 (4)	49.3187	81.6653	2.0314	4.0890	105.2410	335.9671	9.2803	28.2799	450.0013
S8 (5)	49.3185	81.6649	2.0314	4.0890	105.2408	335.9666	9.2802	28.2795	450.0000

TABLE X

DEMAND AND GENERATION SIDE RESULTS FOR THE IEEE 118-BUS SYSTEM

		Before adjustment	After adjustment
Demand side	DCF ^{exc} (ton/h)	91.4	0.0
	DCF ^{sur} (\$/h)	2,102.2	0.0
	DECP	163,563.1	161,439.4
	DEB	165,665.3	161,439.4
Generation side	SCF ^{exc} (ton/h)	648.9	495.2
	SCF ^{sur} (\$/h)	14,924.7	11,389.6
	Generation Profit	35,689.8	35,387.9
	Net Profit	20,765.1	23,998.3

IV. CONCLUSIONS

The framework presented in this paper is a novel solution for the existing gap in this area of research in which only the generation side used to be considered as the main source of emissions. However, generation is driven by demand, and consequently, consumers should be deemed as the prime responsible agents for carbon emissions. In this paper, the carbon footprint is allocated among the consumers using the improved Proportional Sharing Theorem, and then the demands are adjusted to satisfy their carbon footprint limits via an adjustment procedure. Warning signals, such as an excess carbon footprint and its incurred surcharge tax, and incentive information, such as tax exemption and electricity bill reduction, may convince consumers to decrease their demands, and, therefore, reduce carbon footprints. Results show that the proposed framework is beneficial for both the demand and generation sides. The demand side, by supporting the carbon policy and participating in the demand adjustment process, pays a lower electricity bill. On the other hand, from the generation standpoint, unlike the existing policies such as Carbon Cap (CC), Cap and Trade (C&T) and Carbon Tax (CT) where a decrease in demand reduces the benefit, the proposed approach provides a considerable increase in the net profit. The proposed model, compared to the aforementioned policies, shows a lower but reasonable computational efficiency, so the model is fast enough to be applied in online-based problems such as demand side management, market-based problems, etc. A little increase in CPU time is the price to be paid to obtain a fair model that can make effective incentives for both the generation and demand sides without imposing too much cost on society. Future work will apply this framework to a full-fledged carbon market environment.

APPENDIX

In this Appendix, the models of commonly used policies to reduce greenhouse gas emissions such as Carbon Cap (CC), Cap and trade (C&T) and Carbon Tax (CT) are presented. These approaches have been tested in two power systems: 5-bus and IEEE 118-bus. Different loading conditions have been

provided, and the outcomes of each approach before and after demand reduction provide useful information to reveal the potentials and shortcomings of each approach.

A. Models of Greenhouse Gas Emissions Reduction Policies

1) Carbon Cap (CC) Model

The CC model minimizes the total system cost while considering the constraint set (48) and the constraint corresponding to the cap, (49), as follows [40].

$$\min_{\substack{P_{G_i}, Q_{G_i}, V_i, P_{G_i}^M, \\ q_{ij}, \theta_{ij}, P_{ij}, P_{G_i}^M}} F^C = \sum_{i \in \Omega_G} C_i(P_{G_i}) \quad (47)$$

s.t.

$$\text{constraints (2)-(8)} \quad (48)$$

$$\sum_{i \in \Omega_G} Em_i(P_{G_i}) \leq \text{Cap} \quad (49)$$

2) Carbon Cap-and-Trade (C&T) Model

To obtain the C&T model, the objective function considers not only the system total cost but also the term related to carbon permit trade, (50). The deficit in the emissions permit, Em^{defic} , should be considered in the cap constraint (52). Since the trade mechanism among several systems is not considered in this paper, finding the best trade, the optimal value, Em^{defic} , for this single system is used; this way we can compare the best outcome of the C&T policy with the proposed model.

$$\min_{\substack{P_{G_i}, Q_{G_i}, V_i, P_{G_i}^M, \\ q_{ij}, \theta_{ij}, P_{ij}, P_{G_i}^M}} F^C = \sum_{i \in \Omega_G} C_i(P_{G_i}) - \tau \cdot Em^{defic} \quad (50)$$

s.t.

$$\text{constraints (2)-(8)} \quad (51)$$

$$\sum_{g \in \Omega_G} Em_g(P_{G_g}) + Em^{defic} \leq \text{Cap} \quad (52)$$

3) Carbon Tax (CT) Model

The carbon tax is an environmental tax that is levied on the carbon content of fuels. The CT model minimizes the system total cost and the tax-based emission penalty [20].

$$\min_{\substack{P_{G_i}, Q_{G_i}, V_i, P_{G_i}^M, \\ q_{ij}, \theta_{ij}, P_{ij}, P_{G_i}^M}} F^C = \sum_{i \in \Omega_G} C_i(P_{G_i}) + \sum_{i \in \Omega_G} \tau \cdot Em_i(P_{G_i}) \quad (53)$$

s.t.

$$\text{constraints (2)-(8)} \quad (54)$$

B. Comparisons and Discussion

In this subsection, the approaches are considered from both demand and generation sides. To reveal the potentials and shortcomings of the aforementioned approaches, for the 5-bus system, two loading conditions such as 1) initial loading and 2) load increase in bus 2, L2, are studied, while the IEEE 118-bus system is only studied under the initial loading condition. The demand of L2, under the load increase condition, is set to 95 MW. To compare the results of the approaches for the after-adjustment case, the adjusted demands (obtained by the proposed model) are set as the inputs of the three other approaches.

1) 5-bus system

The cap of the 5-bus system is set to 385 ton/h. The cost of

emissions trading is considered to be equal to the carbon tax, \$23/ton [20].

TABLE A1
DEBS OF THE DIFFERENT APPROACHES UNDER FIRST AND SECOND LOADING CONDITIONS, BEFORE AND AFTER ADJUSTMENT, 5-BUS SYSTEM

Approach	DEB (\$/h)			
	First loading condition		Second loading condition	
	Before Adj.	After Adj.	Before Adj.	After Adj.
CC	13,890.35	13,040.19	17,758.69	13,651.43
C&T	24,337.81	22,910.48	28,808.54	23,960.60
CT	24,337.87	22,910.53	28,808.58	23,960.66

a) Demand side:

Table A1 provides useful information on the total DEBs of the different approaches under different loading conditions to show which approach reduces the emissions by imposing lower costs on society.

As can be seen from Table A1, the lowest DEBs are highlighted in boldface. This shows that, among all, the proposed approach performs far better than commonly used policies (i.e., C&T and CT) and better than the CC model. Before adjustment, under the first loading condition, the CC, C&T and CT approaches result in respectively \$147.5/h, \$10,594.97/h, and \$10,595.03/h higher costs than the proposed model, while, after adjustment, they show more or less the same outcomes but \$175.68/h, \$10,045.97/h and \$10,046.02/h higher costs than the proposed approach, respectively. This shows the unacceptable costs that the commonly used policies such as the C&T and CT impose to reduce carbon emissions, while the CC approach is far better than these policies. However, considering the CC approach under the second loading condition and before adjustment, shows that this approach under this loading condition imposes too high costs on society, \$1,541.54/h more than the proposed model. The CPU times of the proposed model for the first and second loading conditions are 0.088 s and 0.239 s, respectively. CPU times of CC, C&T, and CT for the first loading condition are 0.061 s, 0.079 and 0.024s while, for the second loading condition are 0.198 s, 0.283 s, and 0.140 s, respectively. CPU time stands for the whole process (finding LMCs and running OPFs before and after adjustment).

The other important issue to consider is to investigate the impacts of increasing a demand on the DEBs of other demands. In this regard, the changes of DEBs of all demands due to a load increase in bus 2 is depicted in Fig. A1.

Fig. A1. DEB changes due to demand increase in L2, before adjustment.

As can be seen from Fig. A1, by increasing the demand in bus 2, L2, all the approaches result in an increase in the DEBs of the consumers at this bus. For this bus, the outcomes of the proposed approach and the CC approach are more or less similar, while the other two commonly used policies impose much higher costs to this demand. The superiority of the proposed method is revealed when the DEBs of other buses, 3 and 4, are considered with respect to the other approaches. By using the proposed model, the bills of other demands increase only by \$260.54/h and \$251.87/h, respectively, while the other approaches impose much higher costs on these demands. The DEB changes of demand L3 using the CC, C&T, and CT are 364.7% (\$950.18/h), 297.6% (\$775.38/h) and 297.6% (\$775.31/h) higher than the DEB changes obtained by the proposed model, respectively. For L4, the DEB changes of the aforementioned approaches are 161.4% (\$460.54/h), 121.5% (\$360.09/h) and 161.4% (\$360.08/h) higher than the bills provided by the proposed model, respectively. For further analysis, the changes in DES after increasing the demand at L2 for the case after adjustment is portrayed in Fig. A2. As can be seen, after the adjustment process, the proposed approach performs far better than the existing policies. In the proposed approach, the demand increase in L2 results in a higher bill for the consumers at L2 while the impact on the bills of other consumers, by a \$7.43/h increase at L3 and by a \$16.79/h decrease at L4, is negligible. However, the three other approaches cannot provide such fair bills since increasing the demand at L2 not only affects the DEB of the corresponding bus but also the increases on the DEBs of other buses are considerable.

Fig. A2. DEB changes due to demand increase in L2, after adjustment.

Therefore, it can be concluded that the only approach that is fair from the consumers' point of view is the proposed model, since: 1) reduces carbon emissions by imposing the lowest possible costs on society, and 2) responds fairly to likely demand changes at a bus; meaning that if one consumer asks for more energy, it is the prime responsible for this increase and it has to pay more. The DEBs of other demands, as a result of re-dispatching using OPF, always faces changes.

From the consumers' standpoint, simply showing them that their DEBs decrease after a demand adjustment is not an incentive. Actually, incentives are meaningless for those approaches that, first, impose a high cost on the society (C&T and CT) or cannot provide a fair DEB under load-changing conditions (CC, C&T, and CT), asking the consumers to manage their demands to decrease their bills. Therefore, from

the demand standpoint, the only approach that can provide an effective and fair incentive for the consumers is the proposed approach.

b) Generation side:

To show which approach provides a better incentive for the suppliers, the suppliers' net profit changes (due to demand adjustment) under both loading conditions are depicted in Fig. A3, i.e., the bars show the difference between the net profit after demand adjustment and before adjustment condition.

From Fig. A3, it can be concluded that, for the three existing policies (CC, C&T, and CT), not only there is no incentive for the suppliers that motivates them to encourage consumers to decrease their demands, but there is also a deterrent that prevents them from doing so. Using these approaches, the more the demands decrease, the lower their benefits becomes. For example, applying the C&T policy, a load decrease results in a net profit decrease of \$930.29/h and \$3,395.15/h for the first and second loading conditions, respectively.

Consequently, among all the approaches, the only approach that provides effective incentives for the generation side is the proposed approach, in which the demand adjustments result in net profit increases of \$298.49/h and \$817.86/h, respectively.

Fig. A3. Suppliers' net profit changes due to demands' adjustment

2) 118-bus system

The cap of the 118-bus system is set to 6800 ton/h. The cost of emissions trading is considered to be equal to the carbon tax, \$23/ton [20].

Table A2 shows the DEBs of all the consumers as well as the net profits of all the generating units obtained by the different approaches. Boldface figures on the demand side present the approaches that impose lower costs, while, on the generation side, we show the approach that provides an effective incentive to the suppliers. The results show that the CC, C&T, and CT approaches, first, impose too high costs and then provide some incentives. Among the existing policies, the best outcomes are related to the CC approach which, for the before- and after- adjustment conditions, imposes an increase in cost of \$4,518.85/h and \$3,955.91/h, compared to the proposed model. Compared with the proposed approach, C&T imposes \$93,875.69/h and \$91,237.46/h, and CT imposes \$93,875.55/h and \$91,237.44/h higher costs. On the other hand, the proposed approach is the only one that can provide an effective incentive for the suppliers, for which decreasing their demands results in an increase in their net profits of \$3,233.27/h, while the other approaches are deterrent, preventing the suppliers from encouraging consumers to

decrease their demands. The CPU time of the proposed approach for this system is 65.39 s, while the CC, C&T and CT policies require 36.98 s, 58.02 s, and 53.28 s, respectively. The reason why the CPU time of the proposed approach is slightly higher than the other approaches is the time consumed in the adjustment process. This increase in CPU time can be considered as the price of having a fair framework that can provide effective incentives for both consumers and suppliers.

TABLE A2
DEBS AND NET PROFITS OF SUPPLIERS USING DIFFERENT APPROACHES
BEFORE AND AFTER ADJUSTMENT, 118-BUS SYSTEM

Approach	DEB (\$/h)		Suppliers' Net Profit (\$/h)	
	Before Adj.	After Adj.	Before Adj.	After Adj.
CC	168,184.15	165,395.28	39,969.28	30,576.12
C&T	257,540.99	252,676.83	109,729.59	106,848.71
CT	257,540.85	252,676.81	51,464.247	49,649.26
Proposed	163,665.30	161,439.37	20,765.033	23,998.30

REFERENCES

- [1] M. A. Toman and B. Jemelkova, "Energy and Economic Development: An Assessment of the State of Knowledge," *Energy J.*, vol. 24, no. 4, pp. 93–112, 2003.
- [2] M. Mollahassani-Pour, M. Rashidinejad, and M. Pourakbari Kasmaei, "Environmentally-Constrained Reliability-Based Generation Maintenance Scheduling Considering Demand-Side Management," *IET Gener. Transm. Distrib.*, vol. 13, no. 4, pp. 1153–1163, Dec. 2018.
- [3] O. Edenhofer et al., *Climate Change 2014, Mitigation of Climate Change: Working Group III Contribution to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*. Cambridge University Press, 2014.
- [4] "The Global Commission on the Economy and Climate," 2014. [Online]. Available: www.newclimateeconomy.report.
- [5] C. Kang et al., "Carbon Emission Flow From Generation to Demand: A Network-Based Model," *IEEE Trans. Smart Grid*, vol. 6, no. 5, pp. 2386–2394, Sep. 2015.
- [6] S. R. K. L. K. Panwar, B. K. Panigrahi, and R. Kumar, "Modeling of Carbon Capture Technology Attributes for Unit Commitment in Emission-Constrained Environment," *IEEE Trans. Power Syst.*, vol. 32, no. 1, pp. 662–671, 2017.
- [7] B. Zeng, J. Zhang, X. Yang, J. Wang, J. Dong, and Y. Zhang, "Integrated Planning for Transition to Low-Carbon Distribution System With Renewable Energy Generation and Demand Response," *IEEE Trans. Power Syst.*, vol. 29, no. 3, pp. 1153–1165, May 2014.
- [8] H. Saboori and R. Hemmati, "Considering Carbon Capture and Storage in Electricity Generation Expansion Planning," *IEEE Trans. Sustain. Energy*, vol. 7, no. 4, pp. 1371–1378, Oct. 2016.
- [9] M. Sharifzadeh, R. K. T. Hien, and N. Shah, "China's roadmap to low-carbon electricity and water: Disentangling greenhouse gas (GHG) emissions from electricity-water nexus via renewable wind and solar power generation, and carbon capture and storage," *Appl. Energy*, vol. 235, pp. 31–42, Feb. 2019.
- [10] J. Yang, N. Zhang, Y. Cheng, C. Kang, and Q. Xia, "Modeling the Operation Mechanism of Combined P2G and Gas-Fired Plant With CO₂ Recycling," *IEEE Trans. Smart Grid*, vol. 10, no. 1, pp. 1111–1121, Jan. 2019.
- [11] S. Hadayeghparast, A. SoltaniNejad Farsangi, and H. Shayanfar, "Day-ahead stochastic multi-objective economic/emission operational scheduling of a large scale virtual power plant," *Energy*, vol. 172, pp. 630–646, Apr. 2019.
- [12] J. M. Home-Ortiz, O. D. Melgar-Dominguez, M. Pourakbari-Kasmaei, and J. R. S. Mantovani, "A stochastic mixed-integer convex programming model for long-term distribution system expansion planning considering greenhouse gas emission mitigation," *Int. J. Electr. Power Energy Syst.*, vol. 108, pp. 86–95, Jun. 2019.
- [13] D. J. Olsen, Y. Dvorkin, R. Fernandez-Blanco, and M. A. Ortega-Vazquez, "Optimal Carbon Taxes for Emissions Targets in the Electricity Sector," *IEEE Trans. Power Syst.*, vol. 33, no. 6, pp. 5892–5901, Nov. 2018.
- [14] L. Yang, J. Jian, Y. Xu, Z. Dong, and G. Ma, "Multiple Perspective-Cuts Outer Approximation Method for Risk-Averse Operational Planning of Regional Energy Service Providers," *IEEE Trans. Ind. Informatics*, vol. 13, no. 5, pp. 2606–2619, Oct. 2017.
- [15] D. Li, W.-Y. Chiu, H. Sun, and H. V. Poor, "Multiobjective Optimization for Demand Side Management Program in Smart Grid," *IEEE Trans. Ind. Informatics*, vol. 14, no. 4, pp. 1482–1490, Apr. 2018.
- [16] H. Parmesano and T. J. Kury, "Implications of Carbon Cap-and-Trade for Electricity Rate Design, with Examples from Florida," *Electr. J.*, vol. 23, no. 8, pp. 27–36, 2010.
- [17] S. Richey, "The Pros and Cons of Cap and Trade."
- [18] D. L. Crippen, "An Evaluation of Cap-and-Trade Programs for Reducing U.S. Carbon Emissions," 2011.
- [19] D. Adam, "Britain's worst polluters set for windfall of millions," *Guard.*
- [20] F. Yao, Z. Y. Dong, K. Meng, Z. Xu, H. H. C. Iu, and K. P. Wong, "Quantum-Inspired Particle Swarm Optimization for Power System Operations Considering Wind Power Uncertainty and Carbon Tax in Australia," *IEEE Trans. Ind. Informatics*, vol. 8, no. 4, pp. 880–888, Nov. 2012.
- [21] Y. Zhang, H. H.-C. Iu, T. Fernando, F. Yao, and K. Emami, "Cooperative Dispatch of BESS and Wind Power Generation Considering Carbon Emission Limitation in Australia," *IEEE Trans. Ind. Informatics*, vol. 11, no. 6, pp. 1313–1323, Dec. 2015.
- [22] P. Bertoldi, N. Labanca, S. Rezessy, S. Steuwer, and V. Oikonomou, "Where to place the saving obligation: Energy end-users or suppliers?," *Energy Policy*, vol. 63, pp. 328–337, 2013.
- [23] J. Yang, X. Feng, Y. Tang, J. Yan, H. He, and C. Luo, "A Power System Optimal Dispatch Strategy Considering the Flow of Carbon Emissions and Large Consumers," *Energies*, vol. 8, no. 9, pp. 9087–9106, 2015.
- [24] B. Li, Y. Song, and Z. Hu, "Carbon Flow Tracing Method for Assessment of Demand Side Carbon Emissions Obligation," *IEEE Trans. Sustain. Energy*, vol. 4, no. 4, pp. 1100–1107, Oct. 2013.
- [25] F. F. Wu, Y. Ni, and P. Wei, "Power transfer allocation for open access using graph theory-fundamentals and applications in systems without loopflow," *IEEE Trans. Power Syst.*, vol. 15, no. 3, pp. 923–929, 2000.
- [26] J. Bialek, "Tracing the flow of electricity," *IEE Proc. - Gener. Transm. Distrib.*, vol. 143, no. 4, pp. 313–320, Jul. 1996.
- [27] J. Bialek, "Allocation of transmission supplementary charge to real and reactive loads," *IEEE Trans. Power Syst.*, vol. 13, no. 3, pp. 749–754, 1998.
- [28] Y. Cheng, N. Zhang, Y. Wang, J. Yang, C. Kang, and Q. Xia, "Modeling Carbon Emission Flow in Multiple Energy Systems," *IEEE Trans. Smart Grid*, pp. 1–1, 2018.
- [29] T. Sun, D. Feng, T. Ding, L. Chen, and S. You, "Directed graph based carbon flow tracing for demand side carbon obligation allocation," in *2016 IEEE Power and Energy Society General Meeting (PESGM)*, 2016, pp. 1–5.
- [30] A. Rashidinejad, M. R. Habibi, H. Khorasani, and M. Rashidinejad, "A Combinatorial Approach for Active and Reactive Power Flow Tracking," *Int. Rev. Electr. Eng.*, vol. 5, no. 5, pp. 2209–2216, 2010.
- [31] M. Pourakbari-Kasmaei, M. J. Rider, and J. R. S. Mantovani, "An unequivocal normalization-based paradigm to solve dynamic economic and emission active-reactive OPF (optimal power flow)," *Energy*, vol. 73, pp. 554–566, 2014.
- [32] W. Zhang, Y. Xu, Z. Dong, and K. P. Wong, "Robust Security Constrained-Optimal Power Flow Using Multiple Microgrids for Corrective Control of Power Systems Under Uncertainty," *IEEE Trans. Ind. Informatics*, vol. 13, no. 4, pp. 1704–1713, Aug. 2017.
- [33] M. Pourakbari-Kasmaei, M. J. Rider, and J. R. S. Mantovani, "Multi-area environmentally constrained active-reactive optimal power flow: a short-term tie line planning study," *IET Gener. Transm. Distrib.*, vol. 10, no. 2, pp. 299–309, 2016.
- [34] E-Companion, [Online]: "Carbon Footprint Allocation Process," https://drive.google.com/file/d/1oNEYwKjldHV12Y-5povSzmpX_lu02K0h/view?usp=sharing, 2019.
- [35] "Where Carbon Is Taxed." [Online]. Available: <https://www.carbontax.org/where-carbon-is-taxed/>.
- [36] Y. Wang, C. Wang, C. J. Miller, S. P. McElmurry, S. S. Miller, and M. M. Rogers, "Locational marginal emissions: Analysis of pollutant emission reduction through spatial management of load distribution," *Appl. Energy*, vol. 119, pp. 141–150, 2014.
- [37] K. C. Almeida and F. S. Senna, "Optimal Active-Reactive Power Dispatch Under Competition via Bilevel Programming," *Power Syst. IEEE Trans.*, vol. 26, no. 4, pp. 2345–2354, 2011.
- [38] L. Fullarton, *Watts in the Desert: Pioneering Solar Farming in Australia's Outback*. 2016.
- [39] R. D. Zimmerman, C. E. Murillo-Sanchez, and D. G., "MATPOWER," [Online]. Available: <http://www.pserc.cornell.edu/matpower/>.

[40] I. W. H. Parry and W. A. Pizer, "Emissions Trading versus CO₂ Taxes versus Standard," *Resrouces Futur. Washington, DC*, 2007.

Mahdi Pourakbari Kasmaei (S'10–M'15) received his Ph.D. degree in electrical engineering, power systems, from the Universidad Estadual Paulista (UNESP), Ilha Solteira, Brazil in 2015. He was a postdoctoral fellow at UNESP and also a visiting researcher at Universidad de Castilla-La Mancha, Spain, for about 15 months. He was a project executive of three practical projects, PI of three academic projects, and also a consultant in an electric power distribution company. Currently, he is a researcher with the Department of Electrical Engineering and Automation, Aalto University, Finland. He is also the Chairman of IEEE PES Finland IE13/PE31/A34/PEL35 Joint Chapter. His research interests include power systems planning, operations, economics, and environmental issues.

Matti Lehtonen was with VTT Energy, Espoo, Finland from 1987 to 2003, and since 1999 has been a professor at the Helsinki University of Technology, nowadays Aalto University, where he is head of Power Systems and High Voltage Engineering. Matti Lehtonen received both his Master's and Licentiate degrees in Electrical Engineering from Helsinki University of Technology, in 1984 and 1989 respectively, and the Doctor of Technology degree from Tampere University of

Technology in 1992. The main activities of Dr. Lehtonen include power system planning and asset management, power system protection including earth fault problems, harmonic related issues and applications of information technology in distribution systems.

Javier Contreras (SM'05–F'15) received the B.S. degree in electrical engineering from the University of Zaragoza, Zaragoza, Spain, in 1989, the M.Sc. degree from the University of Southern California, Los Angeles, CA, USA, in 1992, and the Ph.D. degree from the University of California at Berkeley, Berkeley, CA, USA, in 1997. He is a Professor with the Universidad de Castilla-La Mancha, Ciudad Real, Spain. His research interests include power systems planning, operations, economics, and electricity markets.

José Roberto Sanches Mantovani (M'06) received the B.Sc. degree from the Sao Paulo State University (UNESP), Ilha Solteira, Brazil, in 1981, and the M.Sc. and Ph.D. degrees in electrical engineering from the University of Campinas, Campinas, Brazil, in 1987 and 1995, respectively. He is currently a Professor with the Department of Electrical Engineering, UNESP. His research interests include the development of methodologies for the optimization, planning, and control of

electrical power systems, and applications of artificial intelligence in power systems.