This is an electronic reprint of the original article.
This reprint may differ from the original in pagination and typographic detail.

Hauksdóttir, Anna Soffia; Ierapetritou, Marianthi; Jämsä-Jounela, Sirkka-Liisa; Zuehlke, Ursula

A decoupling grinding circuit control system

Published in:
IFAC PROCEEDINGS VOLUMES

DOI:
[10.3182/20020721-6-ES-1901.01159](https://doi.org/10.3182/20020721-6-ES-1901.01159)

Published: 01/01/2002

Document Version
Peer reviewed version

Please cite the original version:

Hauksdóttir, A. S., Ierapetritou, M., Jämsä-Jounela, S-L., & Zuehlke, U. (2002). A decoupling grinding circuit control system. *IFAC PROCEEDINGS VOLUMES*, 35(1), 49-54. <https://doi.org/10.3182/20020721-6-ES-1901.01159>

A DECOUPLING GRINDING CIRCUIT CONTROL SYSTEM

Anna Soffía Hauksdóttir ^{*,1} Maranthi Ierapetritou ^{**}
Sirkka-Liisa Jämsä-Jounela ^{***} Ursula Zühlke ^{*}

^{*} Elec. and Comp. Eng. Dept., University of Iceland.

^{**} Dept. of Chem. and Biochem. Eng., Rutgers

^{***} Chem. Dept., Aalto University

Abstract: The problem of simultaneous decoupling and pole placement without cancelling invariant zeros is important, especially in the case of unstable invariant zeros. An experimental model developed of a primary grinding circuit contains such zeros. The simultaneous decoupling and pole-placement problem without cancelling the unstable invariant zeros of the primary grinding circuit is approached by searching for solutions of the nonlinear system of equations composed of the characteristic equation and the decoupling conditions using ideas of an α BB global optimization approach. The simultaneous steady-state decoupling and pole placement problem is then solved for the primary grinding circuit without cancelling invariant zeros using an eigenvector based approach as well as the steady-state decoupling condition. Copyright © 2002 IFAC

Keywords: Grinding circuit control, decoupling, global optimization

1. INTRODUCTION

The decoupling problem has been of interest for many years, as one of the important methods in the control of multiple-input multiple-output (MIMO) systems. The first methods essentially resulted in integrator decoupling, i.e., the resulting diagonal elements were integrators (Gilbert, 1969), (Furuta and Kamiyama, 1977). Those methods were later adapted to include pole-placement decoupling, wherein the diagonal elements contained poles not necessarily at the origin, thus allowing a wider range of dynamical responses to be designed for, see, e.g., (Furuta *et al.*, 1988).

Essentially, a feedforward gain matrix and state feedback are used in a state space representation to achieve the desired result in the classical decoupling methods. In general, state feedback can be used to place poles as well as to affect the element zeros of transfer function matrices in MIMO systems. The invariant zeros (Schrader and Sain, 1989), (Emami-Naeini and

Dooren, 1982) of MIMO systems are, however, not affected by state feedback or feedforward gain. In the classical decoupling methods, the invariant zeros are in general cancelled by a number of the new system poles, thus, effectively leading to an overall reduced-order system.

In many cases, such a decoupled overall reduced-order system results in a first-order differential equation relating the decoupled inputs to the individual outputs, thus, somewhat limiting the dynamical response achievable by the pole placement. Often, this does not pose a major problem, as the first-order response can be shaped by an outer-loop controller, e.g., a PID controller, once the system is decoupled. The fact that the classical decoupling methods cancel all invariant zeros is a much more serious drawback, as in the case of unstable invariant zeros, those are cancelled by unstable controller poles, thus rendering such a controller useless in practice.

It is therefore of interest to explore the design of a decoupling pole-placement controller, that leaves invariant zeros intact and allows full pole placement. This is accomplished in the Faddev algorithm in (Gestsson

¹ This work was supported by the Research Fund of the University of Iceland, the Icelandic Science Fund and NSF grant no. INT-0071505.

and Hauksdóttir, 1995), by imposing the decoupling as well as pole-placement conditions iteratively, easily applicable to low-order systems. The simultaneous decoupling and pole placement problem is approached in (Hauksdóttir and Ierapetritou, 2001), by finding all solutions of the nonlinear system of equations composed of the characteristic equation and the decoupling conditions using the ideas of the α BB global optimization approach proposed by Maranas and Floudas (Maranas and Floudas, 1995).

In this paper, the simultaneous decoupling and pole-placement conditions are presented in Section 2. An experimental model developed of a primary grinding circuit (Jämsä *et al.*, 1983) containing unstable invariant zeros is described in Section 3. The simultaneous decoupling and pole-placement problem without cancelling the unstable invariant zeros of the primary grinding circuit is approached in Section 4 by searching for all solutions of the nonlinear system of equations composed of the characteristic equation and the decoupling conditions using the ideas of the α BB global optimization approach. Expanding the results of (Lohmann, 2000) for the case $D \neq 0$, the simultaneous steady-state decoupling and pole-placement problem is then solved in Section 5 for the primary grinding circuit by finding the state-feedback using an eigenvector based approach without cancelling invariant zeros, and using the steady-state decoupling condition for finding the static feedforward matrix. Conclusions and future studies are discussed in Section 6.

2. SIMULTANEOUS DECOUPLING AND POLE-PLACEMENT CONDITIONS

Consider a square system in a minimal form

$$\begin{aligned}\dot{x} &= Ax + Bu \\ y &= Cx + Du\end{aligned}\quad (1)$$

where $A \in \mathbb{R}^{n \times n}$, $B \in \mathbb{R}^{n \times m}$, $C \in \mathbb{R}^{m \times n}$ and $D \in \mathbb{R}^{m \times m}$. Feedforward and feedback of the form

$$u = Fx + Ev \quad (2)$$

will be applied to decouple the system and to place its poles. The resulting system is then,

$$\begin{aligned}\dot{x} &= [A + BF]x + BEv \\ &= A_{cl}x + BEv \\ y &= [C + DF]x + DEv.\end{aligned}\quad (3)$$

The closed-loop transfer function matrix (TFM) is given by

$$\begin{aligned}G_{cl}(s) &= (C + DF)(sI - A_{cl})^{-1}BE + DE \\ &= \frac{1}{\alpha(s)}(C + DF)Adj(sI - A_{cl})BE + DE\end{aligned}\quad (4)$$

where

$$\begin{aligned}\alpha(s) &= \det(sI - A_{cl}) \\ &= s^n + \alpha_1 s^{n-1} + \dots + \alpha_{n-1}s + \alpha_n \\ &= (s + \lambda_1)(s + \lambda_2) \dots (s + \lambda_n)\end{aligned}\quad (5)$$

denotes the system's desired characteristic equation.

The invariant zeros of a square system are given by

$$\det(CAdj(sI - A)B + Da(s)) = 0, \quad (6)$$

where $a(s)$ is the original systems characteristic equation. Such invariant zeros are neither affected by feedback or feedforward gains, i.e.,

$$\begin{aligned}\det(CAdj(sI - A)B + Da(s)) &= \begin{vmatrix} sI - A & B \\ -C & D \end{vmatrix} \\ &= \begin{vmatrix} sI - A - BF & B \\ -C - DF & D \end{vmatrix} \\ &= \det((C + DF)Adj(sI - A_{cl})B + D\alpha(s)) \\ &= 0.\end{aligned}\quad (7)$$

Further,

$$\begin{aligned}\det((C + DF)Adj(sI - A_{cl})B + D\alpha(s))E \\ = \det((C + DF)Adj(sI - A_{cl})B + D\alpha(s))\det E \\ = 0.\end{aligned}\quad (8)$$

Expanding the adjoint in the numerator part of the closed-loop TFM results in

$$\begin{aligned}(C + DF)Adj(sI - A_{cl})BE + DE\alpha(s) \\ = s^n DE + s^{n-1}((C + DF)BE + \alpha_1 DE) \\ + s^{n-2}((C + DF)A_{cl}BE + \alpha_1(C + DF)BE + \alpha_2 DE) \\ + \dots + (C + DF)A_{cl}^{n-1}BE + \alpha_1(C + DF)A_{cl}^{n-2}BE \\ + \dots + \alpha_{n-1}(C + DF)BE + \alpha_n DE.\end{aligned}\quad (9)$$

Thus, the conditions for decoupling are

$$DE = \text{diag}\{\gamma_1^0, \gamma_2^0, \dots, \gamma_m^0\} \quad (10)$$

and

$$(C + DF)A_{cl}^{(k-1)}BE = \text{diag}\{\gamma_1^k, \gamma_2^k, \dots, \gamma_m^k\} \quad (11)$$

for $k = 1, \dots, n$. It was furthermore shown, that the solution of the simultaneous decoupling pole-placement problem for the case $D = 0$ in (Hauksdóttir and Ierapetritou, 2001) leads to the standard solution wherein all invariant zeros are cancelled if and only if

$$\gamma_i^k = (-\lambda_i)^{(k-1)} \quad (12)$$

for $k = 1, 2, \dots, n$ and $i = 1, 2, \dots, m$, where λ_i are m of the closed-loop eigenvalues.

The simultaneous decoupling and pole-placement problem can now be stated as follows: Simultaneously solve

$$\begin{aligned}\alpha(s) &= \det(sI - A_{cl}) \\ &= s^n + \alpha_1 s^{n-1} + \dots + \alpha_{n-1}s + \alpha_n,\end{aligned}\quad (13)$$

$$C = \begin{bmatrix} -0.8819 & 0 & 0.0433 & 0 \\ 0 & 2.2804 & 0 & -0.6 \end{bmatrix} \quad (22)$$

and

$$D = \begin{bmatrix} 2.6667 & -0.0018 \\ -16.0 & 0.21 \end{bmatrix}. \quad (23)$$

This system has invariant zeros at 0.7143, -0.2222 , -0.2653 and 0.1250 i.e., two unstable ones both due to the input time delays. Assuming the new eigenvalues are selected as -0.7143 , -0.2222 , -0.2653 and -0.1250 , i.e., as the stable invariant zeros which will then be cancelled in the decoupled system and the rest as the negative of the unstable invariant zeros, gives the new characteristic equation

$$\begin{aligned} \alpha(s) &= \det(sI - A_{cl}) = \det(sI - A - BF) \\ &= s^4 + 1.3268s^3 + 0.5574s + 0.0930s + 0.0053 \quad (24) \\ &= 0. \end{aligned}$$

4. SIMULTANEOUS DECOUPLING AND POLE PLACEMENT FOR GRINDING CIRCUIT CONTROL

The primary aim of the controller design is to make the two control loops as independent as possible. This means that changes in the setpoint of the particle size ($Y_1(s)$) do not cause strong effects on the density of the cyclone feed ($Y_2(s)$) and vice versa. Grinding circuit control has been studied e.g. in (Jämsä *et al.*, 1983) and (Niemi *et al.*, 1997).

Assuming an observer has been build for the necessary state estimates and applying state feedback and feed-forward for full decoupling, the off-diagonal elements of the Markov parameters must be zero, i.e.,

$$\begin{aligned} D_1 E_2 &= 0 \\ D_2 E_1 &= 0 \\ (C + DF)_1 (A + BF)^k B E_2 &= 0 \\ (C + DF)_2 (A + BF)^k B E_1 &= 0 \\ \text{for } k &= 0, \dots, 3 \end{aligned} \quad (25)$$

Using $E = (D)^{-1}$ and deriving the characteristic equation coefficients as functions of the F -matrix, results in a total of three linear and nine nonlinear equations to be solved simultaneously for the elements of F .

No solutions to the above system of equations were found using an algorithm based on the ideas of an α BB global optimization approach. One solution, however, was obtained, resulting in close to lower diagonal decoupling and appropriate pole locations, with F given by

$$F = \begin{bmatrix} -0.0411 & 0.3663 & 0.0030 & -0.0451 \\ -2.8597 & 15.3960 & 0.2218 & -0.5768 \end{bmatrix}, \quad (26)$$

and the corresponding step response shown in Fig. 2.

Another solution was obtained, resulting in close to steady-state decoupling and appropriate pole locations, with F given by

Fig. 2. A step response of the resulting lower diagonal decoupled system with simplified input delays.

$$F = \begin{bmatrix} 0.0909 & -0.0223 & -0.0072 & 0.0035 \\ -12.7465 & 5.0123 & 0.6138 & 0.5105 \end{bmatrix}, \quad (27)$$

resulting in the corresponding step response shown in Fig. 3.

Fig. 3. A step response of the resulting steady-state decoupled system with simplified input delays.

5. SIMULTANEOUS STEADY-STATE DECOUPLING AND POLE PLACEMENT FOR GRINDING CIRCUIT CONTROL

In cases where full decoupling and pole placement is not achievable without the cancellation of invariant zeros, steady-state decoupling and pole placement without cancellation of invariant zeros may be possible. In fact, both solutions obtained by the global

optimization approach for the grinding circuit control, were close to such steady-state decoupling.

Consider again the closed-loop system of Eq. (3). In the pole-placement problem, the closed-loop eigenvectors r_i are given by

$$(A - \lambda_i I + BF)r_i = 0 \quad (28)$$

or with slight abuse of notation

$$(A - \lambda I + BF)R = 0 \quad (29)$$

where R contains the closed-loop eigenvectors r_i as columns. Then, in order to cancel invariant zeros, the obtained eigenvectors must be orthogonal to the closed-loop output matrix, i.e.,

$$(C + DF)R = 0. \quad (30)$$

Likewise, in order to avoid cancellation of invariant zeros, the obtained eigenvectors must not be orthogonal to the closed-loop output matrix, i.e.,

$$(C + DF)R = [I \ 0]. \quad (31)$$

Then, one may express both of the above combined as

$$\begin{bmatrix} A - \lambda I & B \\ C & D \end{bmatrix} \begin{bmatrix} R \\ FR \end{bmatrix} = \begin{bmatrix} 0 & 0 \\ I & 0 \end{bmatrix} \quad (32)$$

or

$$\begin{bmatrix} A - \lambda I & B \\ C & D \end{bmatrix} \begin{bmatrix} \Psi_u \\ \Psi_l \end{bmatrix} = \begin{bmatrix} 0 & 0 \\ I & 0 \end{bmatrix}. \quad (33)$$

Then, by solving the combined eigenvector problem, subsequently F can be solved for by

$$F = \Psi_l R^{-1} = \Psi_l \Psi_u^{-1}. \quad (34)$$

Finally, E is solved for such that the steady state TFM is the identity matrix, i.e.,

$$E = (C + DF)(-A - BF)^{-1}B + D)^{-1}, \quad (35)$$

thus, assuring steady-state decoupling. A result for the case $D = 0$ was derived along similar lines in (Lohmann, 2000).

Returning back to the grinding problem, but this time without simplifying the input delays, i.e., applying the Taylor series expansion on the delays of the model

$$Y(s) = G(s)U(s) \quad (36)$$

or

$$\begin{bmatrix} Y_1(s) \\ Y_2(s) \end{bmatrix} = \begin{bmatrix} \frac{-2e^{-8s}}{5s+1} & \frac{0.004e^{-1.87s}}{\frac{3.1s+1}{10e^{-0.93s}}} \\ \frac{3.1s+1}{10e^{-0.93s}} & \frac{-0.15e^{-0.93s}}{s+1} \end{bmatrix} \begin{bmatrix} U_1(s) \\ U_2(s) \end{bmatrix}. \quad (37)$$

Several solutions were found to the steady-state decoupling and pole placement without cancellation of

invariant zeros problem, two of them which are reported here. The first one essentially corresponds to complete lower diagonal decoupling (a special case of steady-state decoupling) maintaining all invariant zeros and is given by

$$F = \begin{bmatrix} -0.0220 & 0.2525 & 0.0018 & -0.0369 \\ -2.5241 & 12.6163 & 0.2077 & -0.3780 \end{bmatrix} \quad (38)$$

and

$$E = \begin{bmatrix} 0.2632 & -0.1238 \\ 30.1934 & -7.0287 \end{bmatrix}. \quad (39)$$

The corresponding step response is given in Fig. 4.

Fig. 4. A step response of the resulting lower diagonal decoupled system.

The second solution is complete steady-state decoupling, again maintaining all invariant zeros and is given by

$$F = \begin{bmatrix} 0.0357 & 0.0242 & -0.0093 & 0.0006 \\ -2.546 & 8.63 & -0.360 & 0.543 \end{bmatrix} \quad (40)$$

and

$$E = \begin{bmatrix} -0.347 & -0.0158 \\ 19.90 & -4.530 \end{bmatrix}. \quad (41)$$

The corresponding step response is given in Fig. 5.

6. CONCLUSIONS AND FUTURE STUDIES

It is known that the general problem of decoupling and pole placement without cancelling the invariants zeros can be solved for some examples, while in other cases no solution exists. In this paper, it was attempted to solve this problem for an experimental model developed of a primary grinding circuit containing two unstable invariant zeros due to input time delays, by

Fig. 5. A step response of the resulting steady-state decoupled system.

placing the system poles such as to cancel stable invariant zeros, but leaving unstable invariant zeros in tact. This was done by searching for all solutions of the nonlinear system of equations composed of the characteristic equation and the decoupling conditions based on the ideas of the global optimization algorithm proposed by Maranas and Floudas (Maranas and Floudas, 1995). No solutions were found to the complete problem, however, solutions were found for the close to lower diagonal decoupling problem as well as the steady-state decoupling problem.

Expanding the results of (Lohmann, 2000) for the case $D \neq 0$, the simultaneous steady-state decoupling and pole-placement problem was solved for the primary grinding circuit by finding the state-feedback using an eigenvector based approach without cancelling invariant zeros, and using the steady-state decoupling condition for finding the static feedforward matrix.

It is of interest to consider other related MIMO problems, such as more general eigenstructure placement problems. It is of particular interest to explore the solution of such control problems using the global optimization approach developed in (Hauksdóttir and Ierapetritou, 2001).

7. REFERENCES

- Emami-Naeini, A. and P. Van Dooren (1982). Computation of zeros of linear multivariable systems. *Automatica* **18**(4), 415–430.
- Furuta, K., A. Sano and D. Atherton (1988). *State Variable Methods in Automatic Control*. Wiley, Chichester.
- Furuta, K. and S. Kamiyama (1977). State feedback and inverse systems. *International Journal on Control* **25**(2), 229–241.

- Gestsson, A. and A.S. Hauksdóttir (1995). Simultaneous decoupling and eigenvalue assignment. In: *Proceedings of the American Control Conference*. pp. 4418–4421. Seattle, Washington.
- Gilbert, E.G. (1969). The decoupling of multivariable systems by state feedback. *SIAM Journal on Control* **7**(1), 50–63.
- Hauksdóttir, A.S. and M. Ierapetritou (2001). Simultaneous decoupling and pole placement without cancelling invariant zeros. In: *Proceedings of the American Control Conference*. pp. 1675–1680. Arlington, VA.
- Jämsä, S.-L., H. Melama and J. Penttinen (1983). Design and experimental evaluation of a multivariable grinding circuit control system. In: *Proceedings IFAC Automation in Mining, Mineral and Metal Processing*. Helsinki, Finland.
- Lohmann, B. (2000). *Complete and partial decoupling by constant state feedback*. Institut für Automatisierungstechnik, Universität Bremen, Germany.
- Maranas, C.D. and C.A. Floudas (1995). Finding all solutions of nonlinearly constrained systems of equations. *Journal of Global Optimization* **7**(2), 143–182.
- Niemi, A.J., L. Tian and R. Ylinen (1997). Model predictive control for grinding systems. *Control Engineering Practice* **5**(2), 271–278.
- Schrader, C.B. and M.K. Sain (1989). Research on system zeros: A survey. *International Journal on Control* **50**, 1407–1433.