This is an electronic reprint of the original article.
This reprint may differ from the original in pagination and typographic detail.

Jämsä-Jounela, Sirkka-Liisa; Vermasvuori, Mikko; Endén, Petri; Haavisto, Sasa
A process monitoring system based on the Kohonen self-organizing maps

Published in:
Control Engineering Practice

Published: 01/01/2003

Document Version
Peer reviewed version

Please cite the original version:
Jämsä-Jounela, S-L., Vermasvuori, M., Endén, P., & Haavisto, S. (2003). A process monitoring system based on the Kohonen self-organizing maps. *Control Engineering Practice*, 11(1), 83-92.

This material is protected by copyright and other intellectual property rights, and duplication or sale of all or part of any of the repository collections is not permitted, except that material may be duplicated by you for your research use or educational purposes in electronic or print form. You must obtain permission for any other use. Electronic or print copies may not be offered, whether for sale or otherwise to anyone who is not an authorised user.

A process monitoring system based on the Kohonen self-organizing maps

S.-L. Jämsä-Jounela*, M. Vermasvuori, P. Endén, S. Haavisto

Laboratory of Process Control and Automation, Aalto University P.O. Box 6100, FIN-02150 HUT, Espoo, Finland

Abstract

Process monitoring and fault diagnosis have been studied widely in recent years, and the number of industrial applications with encouraging results has grown rapidly. In the case of complex processes a computer-aided monitoring enhances operators possibilities to run the process economically. In this paper, a fault diagnosis system will be described and some application results from the Outokumpu Harjavalta smelter will be discussed. The system monitors process states using neural networks (Kohonen self-organizing maps, SOMs) in conjunction with heuristic rules, which are also used to detect equipment malfunctions.

© 2003 Elsevier Science Ltd. All rights reserved.

Keywords:

Monitored control systems; Fault diagnosis; Fault detection; Neural networks; Rule-based systems

1. Introduction

The aim of fault diagnosis systems is to detect process failures at an early stage. The failures can be due to equipment malfunctions or process disturbances. Of these two, process disturbances, where the operating state has drifted outside the acceptable operating area, are usually more difficult to detect. This is due to the fact that acceptable operating area is seldom clearly defined. Detection of process disturbances is important since it reduces the occurrence of production that does not meet the quality criteria. The increase in the quality of the products contributes to a greater economic profitability of the process.

Fault diagnosis has gained growing interest among researchers during recent years. A wide range of applications are reviewed, e.g. in Isermann and Ballé (1997), and current trends in the research field of fault diagnosis in Jämsä-Jounela (2001).

According to Himmelblau (1978), the techniques of fault diagnosis can be divided into two basic categories: estimation of the variables and model parameters, and pattern recognition. Himmelblau (1978) also suggested

that the techniques of fault diagnosis could be classified into the following categories: deterministic, statistical and heuristic types of fault diagnosis.

The first approach in data processing is classification, in which the multi-dimensional symptom vectors are considered and the direction and distance to a reference vector of the nominal state are determined. This is done, for instance, by geometrical or probabilistic methods by artificial neural networks or by clustering (Isermann, 1997). Another approach is to use the heuristic knowledge in the form of heuristic process models, fault-symptom causalities and weighting of the effects (Isermann, 1997). Different diagnostic reasoning strategies can then be applied.

An excellent method for classification, an unsupervised neural network algorithm called self-organizing map (SOM), developed by Teuvo Kohonen (1990), has been successfully used in improving the geometric quality parameters of hot rolled strips as described in Cser, Korhonen, Mäntylä, and Simula (1998). Lassus and Saxén (1998) classified the wall temperatures of a blast furnace by SOM, Deventer, Moolman, and Aldrich (1996) used it in visualizing flotation process disturbances and Ahola, Alhoniemi, and Simula (1999) in monitoring a continuous pulp digester. Excellent results were also obtained when SOM was applied in classification of ore type in the feed of the concentrator by Jämsä-Jounela, Laine, and Ruokonen (1998).

The aim of this study was to develop a fault diagnosis system using Kohonen SOMs in conjunction with heuristics rules.

The system (Vermasvuori, 2001) was tested in the Outokumpu copper flash smelting process. It has three goals. The first goal is to find suitable values for control variables on the basis of the feed type. The second goal is to monitor process states, and the third is to detect process disturbances and equipment malfunctions. The faults monitored in this study are, according to a statistical analysis on the smelting process made by Vapaavuori (1999), the main reasons for production losses.

2. Outokumpu copper flash smelting

Outokumpu flash smelting is a pyrometallurgical process for smelting metal sulphide concentrates. The Outokumpu flash smelting process consists of a flash furnace, waste-heat boiler and electrostatic precipitator. A flash smelter usually also includes the following auxiliary units: feed mixture preparation and drying, converters, slag treatment system, SO₂ fixation system, anode furnace and anode casting.

In flash smelting the fine, dried copper sulphide concentrate and silica flux with air, preheated oxygen enriched air or pure oxygen blast and recycled flue dust are fed through a concentrate burner into the flash furnace reaction shaft. In the reaction shaft the suspension of gas, solid concentrate particles and solid flux particles, are formed and reactions like the one described below take place:

When the suspension leaves the reaction shaft, the reacted molten concentrate particles and inert flux particles are separated from the gas stream and hit towards molten slag and matte. In the molten bath, the reactions are completed and matte and slag will be settled at the settler of the furnace as respective layers due to their different density.

The matte and slag are tapped out through the holes located at the side or at the end walls of the settler. The waste gases generated at the process are ducted through the uptake shaft into waste-heat boiler and electrostatic precipitator.

The sensible heat of the furnace off-gas can be recovered in a waste-heat boiler that is connected directly to the furnace uptake shaft. The waste-heat boiler has two consecutive parts, the radiation section and convection section. On the bottom of the sections there are also dust-collecting boxes for collecting the flue dust. The dust-collecting boxes will receive about half of the flue dust coming into the waste-heat boiler.

Fig. 1. The structure of the Outokumpu flash smelting furnace.

The off-gas and the remainder of the dust flows to the electrostatic precipitator. In the electrostatic precipitator the dust particles are charged in a high-voltage electrical field, caught on a charged plate or wire and finally collected by neutralizing the charge and shaking the wire and plates. Outokumpu flash smelting furnace is presented in Fig. 1.

3. The Kohonen self-organizing maps

The SOM is a neural network algorithm developed by Professor Teuvo Kohonen that forms a two-dimensional presentation from multi-dimensional data. The topology of the data is kept in the presentation such that data vectors, which closely resemble one another, are located next to each other on the map. Another important characteristic of the SOM is generalization of the information, which enables the classification of data vectors not used in the training of the SOM.

The SOMs are applied to classify large amounts of data. They can be used to form a neural network model of an unknown system based only on the data received from the system. In contrast to traditional methods, such as principal component analysis, the Kohonen model can also be created from highly deviating, non-linear data.

Before the SOMs are trained, values of each variable in the data should be normalized to have zero mean and variance of one. This procedure ensures that every variable has equal importance in training the SOM. The following formula is used for the normalization:

$$\hat{x}_k(t) = \frac{x_k(t) - \bar{x}_k}{(1/(n-1)) \sum_{i=0}^{n-1} (\bar{x}_k - x_k(i))^2}, \quad (1)$$

where $x_k(t)$ is the k th component of the measurement vector x , and $\bar{x}_k$ is the mean of all the k th components.

Training a map is an iterative process in which a best matching unit (BMU) must first be found for each data vector. Each data vector must therefore be compared with each neuron on the map in order to find the BMU. A neuron on the map that most closely resembles the current vector is selected as its BMU and the weight

factor of the neuron and its neighbouring neurons are adjusted according to the following formula:

$$w_{ik}(t+1) = w_{ik}(t) + h_{ci}(t)[x_k(t) - w_{ik}(t)], \quad (2)$$

where $w_{ik}(t+1)$ is the new value of the k th component of the weight factor vector of neuron i , $w_{ik}(t)$ is the old value of the k th component of the weight factor vector of neuron i , and h_{ci} is a scalar gaussian kernel function:

$$h_{ci} = \alpha(t) \exp\left(-\frac{\|r_i - r_c\|^2}{2\sigma(t)^2}\right), \quad (3)$$

where $\alpha(t)$ is the training rate factor, $\sigma(t)$ is a factor that implies the size of the effective neighbourhood, and r 's are the coordinates of the neurons.

The SOM can be interpreted by labelling its neurons according to classified measurement vectors. Neurons are labelled after the most probable process state, which can be calculated using the following formula:

$$\text{Prob}_{ij} = \frac{100 \cdot (\text{state})_{ij}}{(\text{total})_j}, \quad (4)$$

where Prob_{ij} is the probability of process state i in neuron j , $(\text{state})_{ij}$ is the number of vectors describing state i in neuron j and $(\text{total})_j$ is the total amount of vectors in neuron j .

This gives the map a clear physical interpretation. However, the weakness of this method is that a neuron normally receives hits from measurement vectors representing both normal and undesired states. Therefore, a neuron cannot be explicitly labelled to represent either a normal or undesired state.

If the SOM is used to detect only one disturbance, neurons can be labelled as disturbance neurons even if the probability for disturbance is less than 50%. The sensitivity of the SOM can be adjusted by using different probability levels when labelling the neurons. If neurons are labelled as disturbance neurons even with a low probability of the disturbance, the SOM will detect disturbances occurring with a high probability, but the number of false alarms will also be high. The probability level that should be used depends on the application.

The state of the process can be monitored by drawing a pointer that displays the neuron corresponding to the latest measurement vector. It is often also advantageous to monitor how the state of the process has evolved during the last measurements, and therefore a suitable length trajectory of the latest neurons representing the latest operational states can be drawn on the map.

4. Fault diagnosis system toolbox

The online toolbox presented in this paper monitors process states using Kohonen SOMs in conjunction with heuristic rules. The system also enables states of

measurements and mathematical methods, based on limit value checking, to be used in heuristic rules.

The system consists of the following modules: process interface, application, databases and user interfaces. The structure of the toolbox is shown in Fig. 2.

4.1. Process interface

The data from process measurements and laboratory and maintenance databases are transferred through the process interface to the toolbox. The toolbox reads data directly through the network from an SQL-based relational database or from a text file.

4.2. Application

After pre-processing, the data are transferred to controllers that distribute the data to measurement, formula and SOM objects. Based on the new measurement data the objects determine their own state. If the state changes, the inference machine is informed accordingly. At the moment there are five state levels available: LOLO, LO, NORMAL, HI and HIHI.

Based on the state changes of measurements and SOM objects, the inference machine updates all those rules where a state has been changed. If all conditions of a rule are evaluated as true, the operator is informed accordingly.

The software model of the equipment consists of input variables, output states and rules. Measurements, formulas, SOMs and other equipment can be defined as

Fig. 2. Structure of the fault diagnosis system.

input variables. Possible output variables are the state of the equipment or state of the process defined for the equipment.

4.3. Databases and analysis

All the measurement data and the rules that have evaluated as true are stored, together with their symptoms and timestamps, in SQL databases for future analysis. The toolbox has several different implemented analysis methods. For example the system can calculate the most typical rules that have been evaluated true in a given time interval. For the use of some specific analysis methods not implemented in the system, the data can easily be exported to other applications through an ODBC interface.

The data stored in the database can also be used for off-line simulations. This is useful during the configuration period, when new rules and SOMs, are tested.

4.4. Graphical user interfaces

The toolbox consists of two different user interfaces. One is developed for the administrator and the other for the operator.

4.4.1. Operator user interface

The operational user interface offers all the information required for on-line monitoring of processes. Through this window it is possible to monitor the current state of a process and even to predict the future trend. The process monitoring user interface consists of four main blocks: maps, trends, active faults and history.

Kohonen Self-Organizing Maps: The SOMs are presented to the user as a collection of red and blue neurons, each neuron being connected to its six neighbours. A totally red neuron represents a fault with 100% probability, a totally blue neuron a totally normal condition of the process and shades in between different probabilities of faults. A gradually darkening line represents a trajectory that shows the most recent process states. One can also take an individual look at the variables used in training the maps and see how the values of each variable are distributed on different neurons of the map. It is also possible to see the distribution of the hits of the training in order to determine whether or not the data were distributed evenly on the map. These are helpful features when analysing the quality of the training.

As SOMs may contain several different types of fault, only the component space of the most probable fault is presented to the operator. This keeps the operator view simple and clear. It is of course possible to examine all the other component spaces of different faults individually or all at once.

Trends: The interface can show two different types of trend: measurement trends and fault probability trends. The measurement trends show the development of individual measurements on a selected time scale. The fault monitoring trends, on the other hand, show the development of the probability of each selected fault of different maps. By examining the trends, it is possible to see which faults have occurred in the near past and which faults are very probably going to occur in the near future.

Active faults: The faults currently occurring in the system are presented to the operator as a list. It contains information about the time instant when each fault was detected, the equipment that the fault is associated with, the actual fault and the symptoms related to the fault. The faults appear in the active faults window when they are detected and are removed automatically when they disappear from the system being monitored. A more detailed description and recovery information are also shown for the selected fault. By clicking on the list with a mouse the selected fault can be changed.

Fault history: The history window can analyse past faults by calculating some statistical averages like mean duration of a fault and the mean time lag between faults. It collects the information from the database in which all the faults are logged immediately after they are detected. Later on the information in the database is updated to mark down the ending times when the faults disappear. Exact time intervals, with an accuracy of one second, can be defined for the history view. An equipment-based view of faults can also be used to analyse the most usual problems of a specified piece of equipment. For the user; the name, beginning and ending times and symptoms are shown. As the rules are chained, it is also useful to inspect only specific symptoms for which the same statistical information as for the faults is available. This inspection of symptoms shows which things contribute in large number of faults and so help to pinpoint the most problematic parts of the process.

The operational window is presented in Fig. 3. Numbers 1–4 represent maps in an on-line state, and 5–8 are the corresponding fault probability trend displays. Number 9 is the fault history window with the four pull-down menus for selecting the desired view. Number 10 is the active faults window and number 11 shows the different pull-down menus and buttons for selecting maps, trends and the other windows.

4.4.2. Administrator user interface

The administrator side, that has all the required components for training of the maps, making of the rules and other general configuration tools, can be made transparent for the operators. As long as it is configured properly, the operator only has to monitor the process without concerning about transfer of data or other

Fig. 3. Fault diagnosis system in on-line use (operator user interface).

modifications. The administrator side has five important blocks: measurements, formulas, SOM training, equipments and trends.

Measurements and formulas: All the measurements that are used have to be defined and they can be given four alarm limits to be utilized in the rules. Each measurement has two low and high limits. Different formulas can be formed from the measurements with basic algebraic operations. The block also supports the selection of maximum or minimum of two or more measurements that can later on be used as training variable for the SOMs.

Training of the SOMs: The most important tool for the engineer is the SOM training block. SOMs can be trained in different sizes and with different parameters. The map size, alpha parameter, number of epochs and the sizes of the neighbourhood in the beginning and the end can be defined. This block also supports the creation of hit-counter-files that can be used to see the distribution of data on the map. These hit-counter-files can be used together to evaluate the efficiency of classification of the map. The first hit-counter-file is formed from the training data, but the latter can be selected freely to test the map behaviour with different evaluation data.

Equipment: Equipment block defines connections between pieces of equipment and measurements and maps related to each piece of equipment. It also has the interface for creating rules. Rules can only be formed from measurements and states defined for the equipment.

Trends: In the trends block it is possible to define which trends of the maps are followed on the operator side. Different fault probabilities can be selected from different maps to one trend display.

In addition, the administrator side also contains a useful database organizer that can be used to prepare data for training of the maps.

The system has an open architecture, which enables easy integration with other applications. It has been

Fig. 4. Fault diagnosis system's administrator user interface.

developed using a platform independent object oriented programming language Java. All the process information like measurements, SOMs and rules are independent from the system so the toolbox application does not need recoding if taken in use in a different process. Fig. 4 depicts different aspects of administrator user interface; number 1 is the measurement window, number 2 the formula window, number 3 equipment window and number 4 representation of an SOM created in SOM window number 5. Window number 6 is for altering databases.

5. Rules in the fault diagnosis system

The most important part of a rule-based fault diagnosis system is the rules that are applied. With well-functioning rules a very effective system can be built while, on the other hand, a system cannot predict phenomena correctly if its rules are false or feeble.

The rules used in the implemented system are IF-THEN rules. In the IF part, objects compared with their limit values can be measurements, values computed from measurements or the probability of phenomena according to the SOMs. Logical operators AND, OR and NOT can be used in the comparison. The THEN part triggers a warning message for the operator, and possibly sets values for other user defined variables, which in turn can be used in the IF part of other rules.

In the system, the rules are always connected to a specific piece of equipment and can be formed using only variables that are known for that equipment. This prevents the insertion of illogical rules that may be the reason why the diagnostic system shows unexpected behaviour. Rules that are based on equipment also make it possible to know which rules are affected if certain changes are made in the process equipment.

An example of the rules used in the system is given below. It can be read "if the gas blower vibrates and

sooting is not detected, then there are dust aggregations in the gas blower”.

IF Gas_blower_SOM_vibration = HI AND Waste_heat_boiler_SOM_sooting = NOT HI THEN Gas_blower_dust_aggregation = HI.

6. Different process phenomena monitored using Kohonen maps

The nature of the phenomena monitored by means of SOMs differs, some of them being closely linked with process control and process disturbances, while the rest monitor the states of the process. For the real-time detection of different phenomena, the SOMs are trained using data that can be received real-time. One exception to this is the map trained using data received from analysis of the feed. The analysis results can be read on-line, but there exists a significant delay between the actual process state and the analysis. This also applies to maps representing the states of the matte and slag, where some of the data are received real-time, while some are based on the analysis of the above two components. These SOMs can be used on-line, the BMU being chosen only on the basis of the available measurements. Thus the SOMs can even operate without all the components of the data vector used in the training. The phenomena associated with process control are presented in Section 6.1, those with process states monitoring in Section 6.2, and those with process disturbances in Section 6.3.

6.1. Process control

The most important phenomenon that affects process control is the quality of the feed material. The overall quality of the feed mixture is influenced by the quality and amount of concentrate and by the amount of recycled slag. In the Harjavalta smelting plant, the quality of the feed material is monitored on the basis of laboratory analyses made, on the average, 5–6 times per day. The composition of the feed material is analysed for its arsenic, lead, zinc, copper, nickel, iron, sulphur, silicate and calcium contents.

The main aim is to train an SOM using information about different feed compositions, and to determine the correct values of the variables used in control for each neuron. The operator can then use the values of the BMU as set points for the control variables.

Determining the value of the oxygen enrichment coefficient: An SOM was trained with the analysis data of the feed material, and the theoretical oxygen enrichment coefficient was monitored as an example of the control variables. Fig. 5 shows the distribution of the enrichment coefficient values on the SOM, as well as a trajectory that represents the process state and the route

Fig. 5. Distribution of the oxygen enrichment coefficient on the Feed type SOM.

it took to arrive at that point. High values of the coefficient are located in the middle-right part of the map, and low values in the upper left-hand corner. The value of the oxygen enrichment coefficient ranges from 139.1 to 164.8. The formation of clusters, i.e. areas on the SOM where the oxygen enrichment coefficient has similar values, implies successful classification.

6.2. Process states monitoring

The overall state of the process was monitored in order to detect undesired process states because a deviation from the desired state cannot always be considered to be a direct process disturbance. From the economic point of view, it is just as important to detect a decrease in the quality of the product as to detect an equipment failure, since both lead to a reduction in productivity and profitability. Differentiating undesired process states from actual disturbances does not generally create sudden emergencies, and thus it is acceptable to detect a phenomenon even with a slight delay.

The monitored process states were viscosity of the slag and the matte, temperature of the waste-heat boiler, and the formation of dust aggregations inside the boiler or the gooseneck. Detection of the formation of dust aggregations is described in detail as an example.

Detection of dust aggregations in the boiler and in the gooseneck: The formation of dust aggregations in the waste-heat boiler decreases heat transfer between the hot gas and the heat exchanger, where superheated vapour is produced by the heat energy of the gas. The formation and detachment of large dust aggregations can also damage the heat transfer equipment of the boiler. The dust accumulating around the gooseneck can, in turn, limit the gas flow through the gooseneck or even clog the pipe through which the gas flows to the gas handling equipment.

To detect dust aggregations, a principal component analysis was first performed in order to reduce the number of training variables. The 19 variables that were direct process measurements, and the eight variables

Table 1

Variables used in the PCA

1	Intake pressure of the furnace
2	Intake pressure of the waste-heat boiler
3	Intake pressure of the electrostatic precipitator
4	Rotational speed of gas blower 1
5	Rotational speed of gas blower 2
6	Flue dust feed
7	Temperature of the waste-heat boiler
8	Temperature of the waste-heat boiler
9	Air feed to the reaction shaft
10	Air feed to oil burners 1–3 of the furnace
11	Air feed to oil burners 4–5 of the furnace
12	Air feed to the reaction shaft + sulphation air
13	Oxygen enriched air feed
14	Sulphation air
15	Load of the dust conveyor
16	Vibration of gas blower 1
17	Vibration of gas blower 2
18	Concentrate feed
19	Weight of the dust silo
20	Flue dust feed + time differential of the weight of the dust silo
21	Time differential of the weight of the dust silo
22	Flue dust feed—load of the dust conveyor
23	Flue dust feed—load of the dust conveyor + time differential of the weight of the dust silo
24	Time differential of the temperature of the waste-heat boiler
25	Time differential of the temperature of the waste-heat boiler
26	1 h average of the temperature of the waste-heat boiler
27	Time differential of the 1 h average of the temperature of the waste-heat boiler

Fig. 6. Latent roots of the principal component analysis of the data collected from the waste-heat boiler.

calculated from the process measurements listed in Table 1, were analysed with the PCA. The latent roots of the PCA can be seen in Fig. 6. An SOM was then trained with the five latent roots that yielded the best results. The resulting SOM is shown in Fig. 7.

Fig. 7 shows that the separation between normal operating conditions and the formation of dust aggregations is relatively clear. Neurons representing the

Fig. 7. SOM used to classify situations in which dust aggregations are formed. **Fig. 8.** SOM used to classify situations in which concentrate aggregations are formed.

formation of aggregations are located in the upper left-hand and the lower right-hand corners of the map.

6.3. Detection of process disturbances and equipment malfunctions

The following actual process disturbances were searched for: flooding of the feed material, aggregation of feed material in the concentrate burner, and malfunctions of the fields of the electrostatic precipitator and gas blower. Detection of the formation of concentrate aggregations in the concentrate burner is described in detail as an example.

Detection of the formation of concentrate aggregations in the concentrate burner: The formation of concentrate aggregations in the concentrate burner obstructs the distribution of feed into the furnace. As obstructed feed does not react completely, this causes other problems, e.g. formation of dust aggregations in the waste-heat boiler and difficulties in controlling the furnace. In order to remove concentrate aggregations from the burner, the feed to the whole plant has to be suspended. These suspensions cause a loss of production and create even more disturbances in the process. In order to detect the aggregations in the burner, an SOM was trained with eight variables: four temperature differences across the reaction shaft, two temperature differences of the shaft cooling water, energy balance of the cooling water, and the amount of concentrate feed to the process. Classification of the concentrate aggregations on the SOM is presented in Fig. 8.

Fig. 8 shows that the neurons representing the concentrate aggregations are located on the lower left-hand and upper right-hand corners of the map.

7. Analysis of off-line testing of the SOMs

After the maps had been trained, their classification abilities were evaluated using data that were not used in training the SOMs. These data consisted of regularly separated, short periods of actual data. The amount of data used for the evaluation was approximately half the size of the data used in the training. The SOMs were subjected to three tests. In the first test, situations in which the data vector hit a neuron representing the same state as the data vector were classified as hits. In the second test, a hit represented a situation in which the data vector hits a neuron where the most probable state is the state of the data vector. In test number three, a hit represented the situation where a data vector's BMU is a neuron that represents the same state as the data vector, or the neuron considers its state as the most probable one. Test number two usually gives better results than number one, but it also causes more false alarms. The third test gives a better result than tests one or two when two or more classification types, i.e. disturbances, occur concurrently.

7.1. Oxygen enrichment coefficient

The feed material SOM was evaluated with data from the middle part of the time period when the data were collected. Classification of the theoretical oxygen enrichment coefficient was tested by dividing the data into different categories on the basis of the value of the coefficient. The classification and amounts of learning and testing data are presented in Table 2. The results of all three tests are given in Table 3.

Table 3 shows that the classification agrees very well with the learning data for values below 140, but the classification becomes more uncertain for higher values. One reason for this is the categorization used, in which, e.g. the values 149 and 150 are placed in different classes even though they are very similar and the difference between them might only be caused by errors in sampling or in the analysis.

7.2. Dust aggregations

An SOM trained with the five latent roots of the principal component model of the variables presented in Table 1 was used to detect dust aggregations in the waste-heat boiler (Komulainen, 2002). All the test results of the classification accuracy of the SOM are given in Table 4.

Table 2

Classification of the oxygen enrichment coefficient

Oxygen enrichment coefficient	Number of cases in the training of the SOM	Number of cases in the testing of the SOM
< 140	315	98
140–149	338	127
150–159	382	185
160–169	324	215
> 169	106	125

Table 3

Test results of the feed type SOM

Oxygen enrichment	Test 1 (%)	Test 2 (%)	Test 3 (%)
< 140	46.9	77.6	77.6
140–149	0.8	7.9	7.9
150–159	0	22.2	22.2
160–169	5.6	20	20
> 169	0	0	0

Table 4

Test 2 results of detecting dust aggregations in the waste-heat boiler

	Amount of test data	Hits	%
Normal	4275	3322	77.7
Aggregations	3994	2932	73.5
Overall			75.6

Table 5

Test 2 results of detecting concentrate aggregations in the concentrate burner

	Amount of test data	Hits	%
Normal	3989	3116	78.1
Aggregations	1009	552	54.7
Overall			73.4

Table 4 shows that 73.5% of the situations in which dust aggregations formed were detected.

7.3. Concentrate aggregations

An SOM trained with the variables presented earlier was used to detect the formation of concentrate aggregations in the concentrate burner (Endén, 2002). All the test results of the classification accuracy of the SOM are given in Table 5.

Table 5 shows that over one-half of the concentrate aggregations were detected.

8. Analysis of on-line testing of the SOMs

Since summer 2001, the fault diagnosis system has been in test use in the Outokumpus Harjavalta copper

smelter. In contrast to the previous study, the focus was on detecting only two types of disturbance; the formation of concentrate aggregations in the concentrate burner, and the formation of dust aggregations in the waste-heat boiler. There were two testing periods in the smelter during last year. During summer 2001, a research assistant carried out his summer training at the smelter, and in November a researcher spent 1 month performing on-line testing of the system. They observed the behaviour of the process, and also recorded more accurate data on the process disturbances. This information was used, together with process measurement data, to form the training data for the SOMs.

The purpose of the on-line testing was to evaluate the behaviour of the system in actual situations, and to set the proper probability level for the maps. Off-line analysis of the concentrate burner SOM showed that, when the probability limit used in labelling the neurons is set to 23, it is able to detect the concentrate aggregations (Table 5). However, at this probability level the proportion of false alarms that occurred when detecting the formation of concentrate aggregations was 61% of all alarms. The effect of changing the probability level value is shown in Figs. 9 and 10.

8.1. Concentrate aggregations

During a period of 1 month, all the actual disturbances detected in the process were noted, and then compared with the notifications of the monitoring system. A process disturbance was considered detected by the system if, at some point during the occurrence of the disturbance, the system gave a notification of it. This made it easier to compare the result with the actual efficiency observed by the operator. The detection of concentrate aggregations in the concentrate burner is presented as an example.

Fig. 9. Detection percentage of process states against different limit values in labelling the neurons.

Fig. 10. Percentage of false alarms in detecting process states against different limit values in labelling the neurons.

Table 6

Test results of the detection of concentrate aggregations in the concentrate burner weighted with the duration of the disturbance

	Direct SOM	Trend SOM
Number of aggregations	753	753
Correct notifications	417	354
Incorrect notifications	151	153
Duration of the notifications	298	299
Detected correctly	55.4	47
False alarms	33.6	33.8

The development of concentrate aggregations in the concentrate burner could be noted by examining the temperature measurements of the reaction shaft. The temperature on one side of the shaft rose every time concentrate had started to gather in the burner. Disturbances in the burner were noted using these measurements, and then compared with the notifications of the monitoring system. The maps were trained with six temperature differences across the reaction shaft and the feed.

During the testing period, two different maps were used to detect the concentrate aggregations. Both were trained with the same training variables, one according to the normal procedure and the other one using a trend of five measurements for each variable. The trend measurements were handled as normal measurements in the training, except that their importance in selecting the BMU was weighted such that the oldest measurements had the least importance.

As disturbances that continue for a longer period of time cause more production losses, the percentages were weighted with the duration of the disturbance. The percentage is calculated by dividing the total length of the detected disturbances with the total length of all the disturbances. The results are presented in Table 6.

However, about one-third of the time the system still incorrectly detects a disturbance. When the maps were

retrained including a new training variable, the energy balance of the shaft cooling water, the trend map was able to reduce the number of incorrect notifications to one quarter of all the notifications, but it could not detect disturbances with the same efficiency. These results are, however, acceptable because over one half of the actual process disturbances were detected. The probability level was searched for and set in such a way that it gave the best balance between correct notifications and false notifications.

9. Conclusions

The system has been in test use at the Outokumpu copper smelter in Harjavalta. A considerable amount of improvement in the results has been achieved during the last year, and the diagnosis system has evolved into a useful tool for process monitoring. In order to achieve even better results, more detailed information about the formation of dust aggregations should be collected. It was also apparent that the two disturbances seem to be linked to one another. After heavy concentrate aggregations there were usually more dust aggregations than normal.

During the 1-month testing period a number of temperature sensors around the reaction shaft started to malfunction, which made it more difficult to test the system. Better instrumentation would enable more precise monitoring of the phenomenon, and make the system less vulnerable to sensor failures. Also, more sensors should be installed to cover a larger area of the shaft walls.

According to the theory, unsupervised neural network models can be constructed solely on the basis of measurement data from the process. However, if we want to label the neurons in the SOM, we also need information about process states. As this cannot be easily measured, we have to rely on the operators'

observations and make the necessary assumptions. This demonstrates that, despite the new modelling methods, process knowledge still plays an important role in fault detection systems.

References

- Ahola, J., Alhoniemi, E., & Simula, O. (1999). Monitoring industrial processes using the self-organizing map. *Proceedings of the SMCia*, Vol. 99, (pp. 22–27).
- Cser, L., Korhonen, A. S., Mäntylä, P., & Simula, O. (1998). Data mining in improving the geometric quality parameters of hot rolled strips. *Proceedings of the ICME 98*, (pp. 265–270).
- Deventer, J., Moolman, D., & Aldrich, C. (1996). Visualisation of plant disturbances using self-organising maps. *Computers in Chemical Engineering*, 20(Suppl.), S1095–S1100.
- Endén, P. (2002). *On-line testing of a process monitoring system and analysis of results*, Master of Science (Tech.) thesis, HUT.
- Himmelblau, D. M. (1978). *Fault detection and diagnosis in chemical and petrochemical processes*. Amsterdam: Elsevier.
- Isermann, R. (1997). Supervision, fault-detection and fault-diagnosis methods—An introduction. *Control Engineering Practice*, 5(5), 639–652.
- Isermann, R., & Ballé, P. (1997). Trends in the application of model based fault detection and diagnosis of technical processes. *Control Engineering Practice*, 5(5), 709–719.
- Jämsä-Jounela, S.-L. (2001). Current status and future trends in the automation of mineral and metal process. *Control Engineering Practice*, 9(9), 1021–1035.
- Jämsä-Jounela, S.-L., Laine, S., & Ruokonen, E. (1998). Ore type based expert system in mineral processing plants. *Particle Systems Characterizations*, 15, 200–207.
- Kohonen, T. (1990). The self-organizing map. *Proceedings of the IEEE*, 78, 1464–1480.
- Komulainen, T. (2002). Report on dust aggregations. *Internal report*, HUT.
- Lassus, L., & Saxén, H. (1998). Tool for classification of blast furnace wall temperatures. *Preprints of the IFAC MMM'98*, (pp. 277–281).
- Vapaavuori, E. (1999). *Performance monitoring of the Outokumpu flash smelting process through principal component analysis*. Licentiate of Science (Tech.) thesis, HUT.
- Vermasvuori, M. (2001). *Online monitoring of disturbances in the Outokumpu copper smelting process*. Master of Science (Tech.) thesis, HUT.